

Ref: BHE/PW/PUR/WR SITES-QAE/2325/Corg-01

Date: 12/11/2020

-----Page 1 of 4-----

To,

ALL BIDDERS,

Sub: Corrigendum-01: Clarifications

Job: FRAMEWORK AGREEMENT (RATE CONTRACT) FOR PROVIDING FIELD QUALITY ASSURANCE ENGINEER SERVICES AT PSWR SITES (THERMAL/GAS BASED PROEJCTS).

E- TENDER SPECIFICATION NUMBER: BHE/PW/PUR/WR SITES-QAE/2325

Bidders to kindly take note of the following:

AA) The following clause is inserted as Cl 10 in Annexure-11: IMPORTANT INFORMATION of NIT and same shall form part of the subject tender:

“Cl 10. Relaxation in Pre-Qualifying Requirement (PQR) for Micro and Small Enterprises (MSE’s) and Startups:

1. Definition of startup shall be in line with Gazette notification No DL 33004/99 dated 19.02.2019 with subsequent amendments, if any.
2. Norms for startups Medium Enterprises in Public Procurement shall be in line with OM no. F.20-2/2014-PPD(pt) dtd 27/07/2017 and O.M. NO. F.20/2/2014-PPD(pt.) dated 20.09.2016 issued GOI, Ministry of finance, Department of expenditure, Procurement policy division, along with D.O. No. 12(11)/2017-SI dtd 22/06/2017 of DoE.
3. Bidder shall keep updated themselves with all related orders/schemes issued by the Govt from time to time, DPIIT portal for start-ups may also be checked.
4. Bidder shall submit Startup recognition certificate (no.) issued by competent authority which shall be checked for authenticity.
5. Startup bidders shall be exempted from the payment of EMD.
6. Provision in the tender document regarding relaxation in prior experience and turnover criteria for Startups & MSE’s as mentioned below:

(a) Technical Pre Qualifying Requirement (PQR) for prior experience:

- i. Technical pre-qualifying requirements is relaxed by 50% (quantities /amount) of the original Pre –Qualifying Requirement specified in the tender (round off to the higher limit or number).

Ref: BHE/PW/PUR/WR SITES-QAE/2325/Corg-01

Date: 12/11/2020

-----Page 2 of 4-----

Further, if the required quantity as per Original PQR is only one (1), then relaxed PQR shall also remain the same, (since quantity is non-divisible in this case.)

- ii. Other Technical Pre-Qualification requirements or any form of licenses or requirements other than stated in **Point no. i** above, shall remain the same for all bidders.

(b) Financial Pre Qualifying Requirement (PQR) Turnover (C.1): Financial pre-qualifying requirements is relaxed by 50% of the original Pre –Qualifying Requirement specified in the tender (round off to the higher limit or number).”

BB) Clarifications

Sl no.	Existing Clause/Reference of VOL I Tech Bid 2325	Bidder's query	BHEL Clarifications
1	CI 5.0 SITE WISE AND AREA WISE DEPLOYMENT OF FQAEs at Pg 50/60	5.1 table has deputation only of Mechanical and Civil but understand that in this project you have Electrical switch board panel , transformers , motors , cabling etc. which may require (E&I) Electrical and instrumentation surveyor also , hence please clarify in the said site wise and area wise deployment for the same.	Tender condition shall prevail. FQAE for E & I, if required shall be confirmed at the time of deployment.
2	Chapter - II: Scope of Works (Pg no. 41/60) mentioned point 3.2.4 on pg.46 of 60 in VOL I Tech Bid 2325.pdf	There is requirement of FQAES for ERECTION & COMMISSIONING OF BOILER & AUXILIARIES , please confirm do you require IBR certified inspection or a mechanical surveyor with qualification i.e. “3.2.4 FQAE for Boiler area and fabrication area shall be additionally qualified ASNT/ISNT Level-II in Non-destructive testing (DPT, MPI, RT, UT) of welds. Minimum one FQAE will be required to be deployed at construction sites in Boiler area and fabrication area. “	IBR certified inspection is not required.
3	-	Please provide us the documentation, fees & procedure that shall be required for getting the gate pass for surveyors at various site.	Requirement depends on customer/particular site & shall be confirmed at time of deployment/execution.

Ref: BHE/PW/PUR/WR SITES-QAE/2325/Corg-01

Date: 12/11/2020

-----Page 3 of 4-----

4	CI no. 13 of Annexure-11: IMPORTANT INFORMATION	Considering the pandemic situation, is COVID test mandatory for the surveyor if yes then please elaborate Tests required, Frequency i.e. for the process and who shall pay for the test required.	FQAE shall follow the state's guidelines for quarantine/Customer's rule for covid 19, which may differ from site to site. If customer require covid 19 test for bidder's FQAE then covid test will be mandatory, test as per Govt. guidelines & bidder shall bear the related cost .
5	-	We have a mix of employee in our organization that is Full time employee and Contract employees hope the same is acceptable.	Acceptable if meets our criteria/required criteria however sole responsibility shall be owned by bidder.
	Reference/BHEL Remark	Existing Clause	Clarification
6	Typographically wrong Mobile no. of AGM/Purchase is mentioned in CI (ix) of table '1.0 Salient Features of NIT'. (Pg 06/60)	LAST DATE FOR SEEKING CLARIFICATION as per contact address given below: 1) Name: P R Chiwarkar Designation: AGM Deptt: Purchase Address: Floor no. 5 & 6, Shree Mohini Complex, 345 Kingsway, Nagpur-440001 Phone: Landline: +91-712-2858-633 Mob: +91-9422805222 Email :prchiwarkar@bhel.in Fax:+91-712-2858600	Name: P R Chiwarkar Designation: AGM Deptt: Purchase Address: Floor no. 5 & 6, Shree Mohini Complex, 345 Kingsway, Nagpur-440001 Phone: Landline: +91-712-2858-633 Mob: - Email :prchiwarkar@bhel.in Fax:+91-712-2858600

CC) EXTENSION OF LAST DATE OF OFFER SUBMISSION

The last date for submission of Tender has been re-scheduled to **17/11/2020, 15.00 hrs.**
Technical Bid shall be opened on **17/11/2020 at 16:00 hrs.**

=====

Ref: BHE/PW/PUR/WR SITES-QAE/2325/Corg-01

Date: 12/11/2020

-----Page 4 of 4-----

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 Clarifications" against TS No.-2325 on e-Procurement Portal of BHEL i.e. <https://bhel.abcprocure.com>.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → www.bhel.abcprocure.com

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

AGM (Purchase)