

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhel.com

Ref: BHE/PW/PUR/SAT-CPS/802/ Corrigendum- 01

Date 05/01/2011

Sub: Corrigendum-01: Issue of Clarification

Page 1 of 1

To

ALL BIDDERS

Tender Specification Number: BHE/PW/PURSAT-CPS/802

JOB: PROVIDING CONSTRUCTION POWER SYSTEM ON "BOO BASIS" (BUILD OWN OPERATE) BASIS, OF 33/11KV & 11/0.433 KV POWER DISTRIBUTION NETWORK, CONSISTING OF TRANSFORMERS , ASSOCIATED EQUIPMENT AND HT /LT CABLING ETC.FOR CONSTRUCTION WORKS OF 2 x 250 MW SATPUDA THERMAL POWER STATION AT MADHYA PRADESH POWER GENERATION COMPANY LIMITED, SATPURA THERMAL POWER STATION, SARNI , DIST: - BETUL (MP)

Bidders to kindly take note of the following:

CLARIFICATION TO QUERIES :

QUERY 01: Refer Item no 3.2.1 b of Chapter – III page no. 22 of 59 of Volume– I-802 : Kindly clarify that Bidder scope is only upto 4 Nos. LT PCC's incomer feeder. Further power distribution is in the scope of the agency working on site to arrange & get the supply from the Outgoing feeder allotted at his own cost & required materials

CLARIFICATION-01: All the installations shall be up to the outgoing feeder of LT Panels.

QUERY 02: Refer Item no 3.2.1 c of Chapter – III page no. 22 of 59 of Volume– I-802 Kindly clarify that all the official fees to get the line, MD Charges, Inspection fee to Electrical inspector office etc are in who's scope.

CLARIFICATION-02: BHEL will pay the charges for getting the sanction of construction power up to 2000 KVA. All other fees/charges are in the scope of bidder.

QUERY 03: Kindly inform about the following items regarding it is in whose scope and its length

CLARIFICATION-03:

- ❖ 33 KV 3 core 50 sq mm HT XLPE cable 33 KV HT VCB TO 2000 KVA
Transformer:100 meters
- ❖ 11KV 3 core 150 sq mm HT XLPE Cable : 100 meters
- ❖ 3.5 Core 300 sq mm LT Armer Alu XLPE Cable : 100 meters

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-802)" against NIT-9296 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,
Yours faithfully,

AGM (Purchase)