

To

ALL BIDDERS

Sub: Corrigendum-01: Amendment to Pre Qualifying Criteria and Technical specification

JOB: SUPPLY (EXCLUDING BHEL SUPPLIED MATERIALS), COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO FABRICATION YARD/ SITE; FABRICATION, ERECTION, ALIGNMENT, BOLTING/ WELDING/ FASTENING, GROUTING, TESTING AND HANDING OVER OF BUNKER STRUCTURES AND RAW COAL BUNKERS AT 1X600 MW VPL (VISA POWER LIMITED) PROJECT NEAR VILLAGE DEVERI & DUMARPALI DISTRICT RAIGARH IN CHHATTISGARH STATE

TENDER SPECIFICATION NO: BHE/PW/PUR/DVRIT-STR/925

Bidders to kindly take note of the following:

=====

AA) AMENDMENT TO PRE QUALIFYING CRITERIA (QR):

Refer QR 'C'- TECHNICAL in NIT: QR 'C' is hereby amended as below:

Bidder must have executed in the last seven (7) years as on 31/10/2011, any one of the following listed Jobs:-

One work of Fabrication and erection of bunker structure of one unit of 190MW or higher.

OR

One work of Erection and commissioning of PF (Pulverized Fuel) Boiler of one unit of 190MW or higher.

Earlier QR 'C' (Technical) mentioned in the tender should be treated null and Void.

BB) AMENDMENT TO PAYMENT TERMS FOR ITEM NO. 2301 (a) :

Few clarifications and query is asked by the bidder is clarified by BHEL as follows:-

SN	Reference clause of Tender Oocument	Existing provision	Bidder query	BHEL CLARIFICATION
1	Vol. I, Chapter VII, Terms of payment (page 51), Stages of pro-rata payments	100% of Item Rate on prorata basis against monthly RA Bills as follows. As per schedule of rate for item No. 2301(a) for fabrication can be further break up a follows: A) Completion of Fabrication: 85% of quoted rate under Item 2301(a) B) Completion of surface preparation and one coat of primer: Balance 20% of quoted rate under Item 2301(a)	As per schedule of Rate for item No. 2301(a), fabrication does not include su rface preparation and one coat of primer. Surface preparation and primer is paid under item No. 2302 separately. Hence 100% of item rate for item No. 2301(a) to be paid on completion of fabrication only before doing surface preparation and prime coat. We request you to amend the te rms of payment accordingly.	Payment for item No. 2301(a) shall be made as per Clause no 10.0 of Chapter -X of SCC and as per clause no: 2.6 of GCC

2	Part II, Price Bid BOQ Item No. 2305	Providing and applying two coats of epoxy resin based paint pigmented with Titanium dioxide with minimum OFT of 100 microns. Top coat shall consist of one coat of epoxy paint suitably pigmented of approved shade and colour with glossy finish and OFT of 75 microns. Additionally finishing coat of polyurethane of minimum OFT of 25 microns shall be provided"	We understand that the following coats are to be applied to meet the total requirement of item No.2305. 1 epoxy paint suitably pigmented of approved shade and colour with glossy finish. One coat of OFT 75 micron. 2. finishing coat of polyurethane -one coat of minimum 25 micron OFT. The total thickness of paint coats(OFT) is 100 micron for item No 2305 and 100 microns for item 2302. Please confirm immediately.	Tender conditions are clear and holds good and the bidder shall be abided by the same
3	Part II, Price Bid BOQ Item No. 2302	As per Vol. I, Chapter VII, Terms of payment(Page 51), 100% of item rate on prorata basis against monthly RA Bills	We want 75% of the item rate paid after blast cleaning and application of one coat of shop primer. Balance 25% after application of second coat of primer.	Tender conditions are clear and holds good and the bidder shall be abided by the same
4	Part II, Price bid BOQ Item No.2305	-DO-	We want 60% of the item rate payment on application of top coat and 40% of the item rate payment on application of finishing coat.	Tender conditions are clear and holds good and the bidder shall be abided by the same

CC) AMENDMENT TO THE DUE DATE OF OFFER SUBMISSION:-

Due date of offer submission is reschedule as follows:-

DUE DATE & TIME OF OFFER SUBMISSION: - Date: 03/12/ 2011, Time: 15.00Hrs

OPENING OF TENDER: - 1 hours after the latest due date and time of Offer submission

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01" against NIT-10802 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

DGM (Purchase)