



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-23-Jul-20

CORRIGENDUM- 01

PROJECTs	:	4 X 210 MW NTPC Kahalgaon- R&M (ESP)
PACKAGE	:	HVAC SYSTEM FOR R&M PROJECTS
ENQUIRY NO	:	PE/PG/NTK/E-6475/2020 Dated 16.07.2020
SUBJECT	:	OTHERS-SCOPE OF CONSTRUCTION POWER AND WATER

Type of Corrigendum			
Technical Corrigendum -	☐	Commercial Corrigendum -	☒

Please note the following scope of Construction Power and Water at site-

Construction Power- The Contractor shall submit to the customer within thirty (30) days from the date of acceptance of the LOAs, his electrical power requirement, if any, to allow the planning of the same by the customer. The Contractor shall be provided with free supply of electricity for the purpose of execution of the contract at one point only at customer's work site at 415 V voltage level. The Contractor shall make his own further distribution arrangement and shall maintain a minimum drawal power factor of 0.8, and all such devices for maintaining power factor of 0.8 or better shall be under the scope of contractor. All temporary wiring must comply with local regulations and will be subject to customer inspection & approval before connection to supply. The free supply of power will not be provided for the use in the labour and staff colony.

Power supply for labour & staff colony shall be provided at one point within the plant boundary either at 11 kV or 415V depending on quantum and distance. It shall be the responsibility of the contractor to take the power supply upto the point of his use. The supply of electricity for labour & staff colony shall be charged at rates prevalent at the site.

Construction Water- Contractor shall make all arrangements himself for the supply of construction water as well as potable water for labour and other personnel at the work site/colony

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Upendra Chaudhary
Manager/BOP