



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-4-Aug-20

CORRIGENDUM- 01

PROJECT	:	4 X 225 MW Arun-3 HEP, Nepal
PACKAGE	:	D/G EOT CRANES UP TO 100T
ENQUIRY NO	:	PE/PG/ARN/E-6482/2020 Dated 04.08.2020
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

In reference to the above mentioned tender enquiry for **D/G EOT CRANES UP TO 100T** package

Please note the following changes

1. Due date has extended from 4-Aug-20 to 7-Aug-20 till 11:00 AM. Bid opening shall be done at 02:00 PM on the due date.
2. BHEL Replies to pre-bid queries (Annexure-A attached).

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP



4x225 MW ARUN-3 HEP NEPAL

**100/20T TRANSFORMER CAVERN AREA
DOUBLE GIRDER EOT CRANE**

SPECIFICATION No: : PE-TS-437-501-A003

SECTION-III

REV 0

DATE 01.08.2020

Annexure-A

SECTION-III

PRE BID CLARIFICATIONS - 1



4x225 MW ARUN-3 HEP NEPAL

100/20T TRANSFORMER CAVERN AREA
DOUBLE GIRDER EOT CRANE

SPECIFICATION No: : PE-TS-437-501-A003

SECTION-III

REV 0

DATE 01.08.2020

PRE-BID CLARIFICATIONS-1

S. No.	Section/Clause/Page No.	Statement of the referred clause	Clarification Required	BHEL's clarification
1	cl.no.1.1., page no.4 of technical specification		Please note capacity of the crane & we have considered 1No.100/20T Crane as per page no.289 cl.no.1.71. & as per clearance diagram page no.232, but in your technical datasheet PE-TS-437-501-A003 page no.7. cl.no.1.1 - mentioned 1No.100/320T we presume its wrongly mentioned just typographical error from BHEL. We are quoting 1No.100/20T Crane for Enquiry No-PE/PG/ARN/E-6482/2020 4x225 MW Arun-3 Hydro Electric Project, Nepal.	Bidder's understanding is correct.