



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-9-Oct-20

CORRIGENDUM- 01

PROJECTs	:	3X200+3X500+1x500 MW NTPC KORBA TPP-FGD, 4X250 MW BRBCL NABINAGAR FGD, 3x660 MW NPGCPL NABINAGAR STPP (FGD PKG), 2 X 250 MW NSPCL Bhilai TPP FGD
PACKAGE	:	HVAC FOR FGD
ENQUIRY NO	:	PE/PG/KR1/E-6525/2020 Dated 23.09.2020
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

Bidders are requested to go through the following changes

1. Replies to pre-bid clarifications attached.
2. Refer attached technical amendment -1.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Upendra Chaudhary
Manager/BOP

PRE BID CLARIFICATION REPLY**ENQUIRY NO.****PE/PG/KR1/E-6525/2020****PACKAGE:****HVAC FOR FGD****PROJECTS:****3X200+3X500+1x500 MW NTPC KORBA TPP-FGD****4X250 MW BRBCL NABINAGAR FGD,****3x660 MW NPGCPL NABINAGAR STPP (FGD PKG),****2 X 250 MW NSPCL BHILAI TPP FGD**

SL. NO	CLARIFICATION REQUIRED	BHEL REPLY
1.	Kindly confirm if Underdeck Insulation/ insulation of slabs above / below the conditioned spaces and roof of space exposed to Sun is included in the HVAC Bidder's scope as the same is not figuring in BOQ. It is observed that in Spec relating to NTPC- Korba (3 X 200 MW + 3 X 500 MW + 1 X 500 MW), in page 62/250 / Clause 12 it is specified that the Underdeck Insulation is not in scope of HVAC Bidder, the same is not found in specs related to the other sites.	Underdeck Insulation is not in HVAC Bidder scope. Please refer Amendment No. 1 to the specification.
2.	Capacity of AHUs (BOQ Sl no.1b1,2b1,3b1 & 4b1) have not been disclosed by your good selves. Hence, we request your good selves to kindly confirm the capacities of AHUs	Capacity of AHU shall correspond to the condensing unit capacity mentioned in the specification for the respective projects. Fan Flow Rate shall be decided during detail engineering.



HVAC FOR FGD
4X250 MW BRBCL NABINAGAR FGD,
3x660 MW NPGCPL NABINAGAR STPP (FGD PKG),

SPECIFICATION NO. PE-TS-457/463-
(571-13000-A)-A001

AMMENDMENT-1

DATE: 09/10/20

SHEET 1 OF1

AMENDMENT TO EXISTING CLAUSES OF TECHNICAL SPECIFICATION

Sl. No.	Clause	Existing description	To be read as (Amendment)
1	3x660 MW NPGCPL NABINAGAR STPP TECHNICAL SPECIFICATION NO. PE-TS-457-(571-13000-A)-A001 SECTION-I, SUB-SECTION : C 2A, CLAUSE NO. 7.01.00 (12), PAGE NO. 62 OF 525	Requirement of Underdeck insulation (for AC Areas)	Requirement of Underdeck insulation (for AC Areas) – (Not in Bidder's Scope)
2	4X250 MW BRBCL NABINAGAR FGD TECHNICAL SPECIFICATION NO. PE-TS-463-(571-13000-A)-A001 SECTION-I, SUB-SECTION : C 2A, CLAUSE NO. 7.01.00 (12), PAGE NO. 64 OF 523	Requirement of Underdeck insulation (for AC Areas)	Requirement of Underdeck insulation (for AC Areas) – (Not in Bidder's Scope)