

Bharat Heavy Electricals Limited Power Sector-Western Region

Shreemohini complex, 345 - Kingsway Nagpur -440 001

Date: 27/01/2009

04 फैक्स FAX: 0712-3048698-699/3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/HZGG-TG/628/Corrigendum 02

To

ALL BIDDERS

SUB: Clarifications and Extension of Last Date of Offer submission.

JOB: ET&C GT, GTG, ST, STG etc at 1X350MW CCPP at Vill Mora Hazira, Gujarat.

TS NO: BHE/PW/PUR/ HZGG-TG/628

Please refer Tender Specification for the subject job detailed above. All bidders are requested to take note of the following

AA) CLARIFICATIONS TO THE QUERIES

QUERY 1: Delivery schedule of Steam Turbine & Steam turbine Generator reg::

CLARIFICATION TO QUERY 1: Tentative delivery schedule of Steam Turbine & Steam Turbine Generator is June . July -2009. However, in view of the transportation & other procedural constraints a gap of 3 to 4 months between the delivery of both the equipments is expected. Contractor shall make arrangements for lifting, shifting, placement etc of equipments as per the arrival of each equipment at site. No any other claims on such account will be entertained.

QUERY 2: Terms of payment for placement of HP-IP Turbine and Generator stator reg: **CLARIFICATION TO QUERY 2**: Terms of payment given in Section 12 of tender specification holds good.

QUERY 3: Equipment drawings of combined HP/IP (K) module of Steam Turbine & Steam Turbine Generator reg:

CLARIFICATION TO QUERY 3: Typical drawings for HP-IP(K) combined module of Steam Turbine and Steam Turbine Generator are uploaded as file titled Generator drwg-628+and Turbine drwg-628+.

QUERY 4: Elevation of Steam turbine foundation reg:

CLARIFICATION TO QUERY 3: Clause No.4.8.4 of tender specification holds good.

QUERY 5: Standard Length of CW pipe & edge preparation reg::

CLARIFICATION TO QUERY 3: Pipes of standard 10m length shall be supplied for CW piping. CW pipe fittings like bends, tees, elbows, reducers etc will be supplied duly edge prepared. However for any site cutting for site requirements/site work, the preparation of edges shall be carried out by the contractor as a scope of work at site.

BB) CORRECTION IN SECTION-12

1. Clause 12.1.4, sl.no.2 i.e. **percentage rates** for %Application of anti corrosive tapping+shall be read as **70% in place of 60%**



Bharat Heavy Electricals Limited Power Sector-Western Region Shreemohini complex, 345 - Kingsway Nagpur-440 001

Date: 27/01/2009

04 फैक्स FAX: 0712-3048698-699/3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/HZGG-TG/628/Corrigendum 02

CC) EXTENSION IN LAST DATE OF OFFER SUBMISSION

Last date of offer submission is rescheduled to 03/02/2009. Technical bid shall be opened on 04/02/2009

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidders unqualified acceptance of this corrigendum.

This letter is hosted as file titled %Corrigendum-02 (Clarification & Time Extn-628)+against NIT-5894 in BHEL web page (www.bhel.com Tender Notifications View Corrigendum).

Thanking you,

Yours faithfully,

DGM (Purchase)