

Ref: BHE/PW/PUR/UKT-STG/651/Corrigendum-02

Date 04/06/2009

-----Page 1 of 1-----

To  
ALL BIDDERS,

**Sub: Corrigendum-02: Clarifications and Extension of last date of offer submission.**

**JOB:** COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO SITE; ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF TURBINE AND GENERATOR SET AND ITS AUXILIARIES, HP/LP HEATER AND DEAERATOR, POWER CYCLE PUMPS, CIRCULATING WATER PUMPS, AUXILIARY COOLING WATER PUMPS, ASSOCIATED PIPINGS ON LINE CONDENSER TUBE CLEANING SYSTEM, CONDENSATE POLISHING UNIT INSULATION AND FINAL PAINTING ETC OF 1X500 MW Unit-6 at Gujarat State Electricity Corporation Limited, Ukai Thermal Power Station , Ukai, Dist.- Tapi (Gujarat)

**TS No. BHE/PW/PUR/UKT-STG/651**

Bidders to kindly take note of the following:

=====

**AA) CLARIFICATIONS TO THE QUERIES**

**QUERY 1: Weight of CW Piping:**

**CLARIFICATION:** Weight of CW Piping is not included in Appendix II of tender specification. However approx weight of CW pipes under the subject tender is: 320 MT.

**QUERY 2: Wrapping and Coating Works of CW Piping reg:**

**CLARIFICATION:** CW piping shall be encased by concrete by civil agency once the pipe erection is cleared by TG agency for doing the encasing work.

**QUERY 3: Condenser Tubes Details reg:**

**CLARIFICATION:** Approximate details of condenser tubes are as given below:

1. Approx.Qty :24500 Nos.
2. Approx. Weight: 200MT

**QUERY 4: Lining & Insulation reg:**

**CLARIFICATION:** Spray insulations application (LP Bypass valve, HP, IP, ESV & IV) is not covered in the scope of the subject tender.

**BB) EXTENSION OF LAST DATE OF OFFER SUBMISSION**

The last date for submission of Tender has been re scheduled to 10/06/2009, 18.00 hrs.

Technical Bid shall be opened on 11/06/2009 at 11.00 hrs

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-02 (Time Extn & Clarification-651)" against NIT-6463 in BHEL web page ([www.bhel.com](http://www.bhel.com))→Tender Notifications → View Corrigendum).

Thanking you,  
Yours faithfully,

DGM (Purchase)