

Ref: BHE/PW/PUR/1901191/Corg-02

Date: 04/03/2020

-----Page 1 of 2-----

To
ALL BIDDERS,

Sub: Corrigendum-02: Issuance of clarification of Queries raised by bidder

Reference:

1. **E-Tender Spec. No:** 1901191
2. **Scope of work:** Supply of MS Deck sheets for 3 X 800MW PVUNL Patratu STPP Project, Dist.- Ramgarh, Jharkhand on 'F.O.R.' Destination basis.

Corrigendum Ref: -

Sl. No.	Corrigendum Ref	Corrigendum Type
1	Corrigendum-01	Time extension

Bidders to kindly take note of the following:

AA) Clarification

Sl no	Reference clause of Tender Document	Bidder's Query	BHEL Reply/Clarification
1	Chapter IV. Techno – Commercial Terms and Conditions: Part – I: Technical specification, Cl. NO. 1, BOQ item No. A1502 (a & b) and B1502 (a & b)	As per BOQ Items A1502 a & b and B1502 a & b, the thickness in all the items is mentioned 0.80mm Thick BMT whether it is Span of 1800mm or Span exceeding 1800 – 2500MM. In this connection we wish to state that the thickness of 0.80mm thick BMT in case of 1800 – 2500MM shall not work out rather higher thickness shall be required. The actual thickness shall be arrived based on your tender specification parameters. Hence, we request you to please let us know what thickness is to be considered for the Sl. No. "b" in both the items (i.e. BOQ item No. A1502(b) and B1502(b)).	As per BOQ item No A1502 (a & b) and B1502 (a & b) design of deck sheet for the load and span indicated is in bidder scope. The thickness of 0.8mm mentioned under BOQ items is the minimum requirement. Accordingly, thickness to be decided by bidder as per load and span indicated. Bidders are also required to furnish the design document as per relevant IS code in support of load carrying capacity.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

Ref: BHE/PW/PUR/1901191/Corg-02

Date: 04/03/2020

-----Page 2 of 2-----

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → www.bhel.abcprocure.com

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

AGM (Purchase)