



**CORRIGENDUM-2**  
**PRE-BID CLARIFICATION**

**PROJECT: Khurja STPP (2x660MW) project**

**ENQUIRY NO: 77/22/6001/BPA**

**ITEM: DG Set & Accessories**

SL NO	VOLUME/ SECTION	PAGE NO.	CLAUSE NO.	TECHNICAL SPECIFICATION/ TENDER DOCUMENT	COMPLETE DESCRIPTION OF QUERIES	BHEL REPLY DATED 19.04.2022
<b>REPLY TO TECHNICAL QUERIES</b>						
1	Technical Specification. V.14:- MANDATORY SPARES	13 of 23	C.4	Fuel nozzles and needles - 1 Set	Please note that in Diesel Generator Set Injector shall be supply as mandtaory spare instead of Fuel nozzles. Also in 1 complete engine 16 nos Injector required, But practically all injector cannot stop working or get faulty at same time. Either 1 or maximum 2 nos Injector can get faulty or stop working. Practically 1 nos Complete Injector required. shall we can supply 1 nos complete injector as 1 set.	1 Set ( 16 nos.) of Fuel/ Injector nozzles to be considered under this head. Wherever fuel nozzles not applicable ,1 Set (16 nos.) of "Injector cup" may be considered.
2		13 of 23	C.5	Piston, complete with rings and rod -1 Set	In similar way in 1 complete engine 16 nos Piston complete with ring and Rod required, But practically all Piston complete with ring and rod cannot stop working or get faulty at same time. Either 1 or maximum 2 nos Piston can get faulty or stop working. Practically 1 nos Complete Piston complete with rings and rod required. shall we can supply 1 nos complete Piston with rings and rode as 1 set.	1 Set of Piston complete with rings and rod means as required for 1 complete engine. For a 16 cylinder engine - Bidder to consider 16 nos. Piston complete with rings and rod