

	TITLE: 1x800 MW WANAKBORI STPP TECHNICAL SPECIFICATION FOR SIDE STREAM FILTRATION PLANT	SPEC NO: PE-TS-408-181-A001	
		VOLUME: II-B	
		SECTION: E	
		REV NO: 01	DATE:

ANNEXURE-II (REV-01)**LIST OF MANDATORY SPARES**

S.no.	Mandatory Spares	Total Quantity
1.0	Valve	10% of total quantity used for each type, class and size or two (2) numbers for each type, class and size whichever is maximum.
2.0	Field Instruments (Transmitters/ temperature elements (TC / RTD) / Gauges / Switches etc. along with relevant accessories)	10% of total quantity used for each type or one (1) number for each type whichever is higher along with accessories.

1