



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-24-Jul-20

CORRIGENDUM- 02

PROJECTs	:	2X660 MW UDANGUDI SUPERCRITICAL STPP
PACKAGE	:	D/G EOT CRANES UP TO 100T
ENQUIRY NO	:	PE/PG/UDN/E-6428/2020 Dated 30.06.2020
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

In reference to the above mentioned tender enquiry for **D/G EOT CRANES UP TO 100T** package

Please note the following:

Sl no.	BHEL Technical Specification Clause	Remark
1	Clause no. 2.0.0 (cc)- (page 43 of 208 of technical specification PE-TS-435-501-A401)	Clause stands withdrawn.
2	Clause no. 2.1.0 (I)- requirement of master controller (page 34 of 208 of technical specification PE-TS-435-501-A401)	For DG EOT upto 100T, master controller not required. Hence the same indicated in technical specification stands withdrawn.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Upendra Chaudhary
Manager/BOP