

पावर सेक्टर- पश्चिमी क्षेत्र Power Sector-Western Region
श्रीमोहिनी कॉम्प्लेक्स, 345 किंग्सवे, नागपुर Shreemohini complex, 345 Kingsway Nagpur - 440 001
फोन / Phone 0712- 3048600, फैक्स FAX: 0712- 3048699 www.bhelpswr.co.in

Ref: BHE/PW/PUR/MADT1-STR U-3 & U-4/1212-1213/Corrigendum 02

Date 15/02/2014

To

ALL BIDDERS

Sub: Corrigendum-02: Out-come of Pre Bid Discussions held on 11/02/2014.

JOB:

A) Supply Job:- Detailed drawing preparation and getting approval from BHEL PEM / NTPC, supply of finished product of bunker structures, raw coal bunkers, coal handling transfer points, coal conveyor galleries and its supporting trestle of bunker structures etc. at site of Unit # 3 & Unit # 4 of 2X660 MW NTPC MOUDA STPP STAGE II.

B) E & C Job:- Unloading, receipt & handling of finished material; pre assembly, erection, alignment, bolting/ welding/ fastening, grouting, testing, final painting and handing over of bunker structures, raw coal bunkers, coal handling transfer points, coal conveyor galleries and its supporting trestle of bunker structures etc. at site of Unit # 3 & Unit # 4 of 2X660 MW NTPC MOUDA STPP STAGE II.

Sl no	Tender specification number	Unit number & project
1	BHE/PW/PUR/MADT2-STR U-3 /1212	Unit 3 of 2x660 MW bunker structure
2	BHE/PW/PUR/MADT2-STR U-4 /1213	Unit 4 of 2x660 MW bunker structure

As per the schedule, Pre-bid discussions of the subject tender were held on 11/02/2014. Clarification sought by the prospective bidders during the meeting and the BHEL reply to them are as below::

AA) Brief of Discussions during Pre-bid meeting held on 11/02/2014

Sl. No.	Bidder's Query	BHEL's clarification
1	Bidders have represented that, Ring Beam of Bunker Shells shall be around 40 MT and hence transportation of same shall be practically impossible. They have further requested for permission of fabrication of Ring Beam for shells at site.	BHEL Clarified that fabrication of Ring Beam for Bunker Shell shall be permitted at site.
2	Bidders have asked 40,000 Sqm area (space) for Assembly of Fabricated Columns & other structural items at site.	There is space constraint at site and so much area is not feasible. However space shall be provided at site as per availability of the same.
3	Bidders have requested for furnishing the GA drawings	GA drawings are uploaded herewith as file titled 'Drawings -1212-13'
4	Set of 50 MT Jacks are not enough for carrying out optional shell erection by Strand Jack Method	BHEL clarified that erection of complete shell is not permitted in case of strand method is opted. One shell at a time shall be lifted and hence set of 50 T strand jack is sufficient
5	Bidders have asked about procurement of brought out item in the scope of work under this tender.	BHEL explained that procurement of brought out item may be done either by Prime Bidder or the Consortium Partner

पावर सेक्टर- पश्चिमी क्षेत्र Power Sector-Western Region
श्रीमोहिनी काम्पलेक्स, 345 किंग्सवे, नागपुर Shreemohini complex, 345 Kingsway Nagpur - 440 001
फोन / Phone 0712- 3048600, फैक्स FAX: 0712- 3048699 www.bhelpswr.co.in

Ref: BHE/PW/PUR/MADT1-STR U-3 & U-4/1212-1213/Corrigendum 02

Date 15/02/2014

		based on understanding between the two. However bill/invoice shall be raised by the prime bidder only.
6	Bidder also asked the information regarding Engineering Drawing and procedure of preparation, submission and approval of detailed fabrication drawings.	BHEL clarified that, BHEL will provide basic engineering drawing and most of the drawings have been released. Bidder has to appoint detailer with due approval from BHEL/NTPC. Detailer will prepare, submit and get approval of detailed Fabrication Drawing from BHEL Engineering Division (PEM), Noida.
7	Bidders have sought clarification wrt the invoicing pattern for Consortium, wherein Prime Bidder is outside Maharashtra agency (for E&C Portion) and Consortium Partner (for Supply portion) is Maharashtra based party.	Since the supplies shall be made from within Maharashtra, in such case, the prime bidder has to be registered under Maharashtra VAT and issue Maharashtra VAT invoice. In this case, even if the bidder's quote is inclusive of VAT or Nil VAT, they have to provide Maharashtra VAT invoice showing the value of VAT separately.
8	Bidders have requested to clarify whether BHEL will evaluate the price on landed cost or on total cost including taxes as there may be additional implication on account of VAT for Maharashtra State bidder as compared to outside Maharashtra Party.	BHEL clarified that Evaluation will be on total cost basis including taxes.

BB) Clarification to PQR B.1 a

In case any bidder (say XYZ), has two manufacturing Units registered in the same name of XYZ, though with different Excise Registration in different States, their combined credentials shall be considered for PQR evaluation.

CC) Revision in Volume II Price Bid

In view of certain errors observed in Section A of Vol II Price Bid specification, same has been revised and **entire revised price bid is uploaded as file titled 'Voll II Price Bid Rev 01 dated 14/02/2014'.**

Bidders may kindly note that, price bid is required to be submitted in the Revised format.

In case any bidder submit their price bid in old format, then Unit Rate, Taxes and freight quoted by the party in old format shall be considered and total price shall be calculated by BHEL based on the quantities indicated in revised price bid format 'Voll II Price Bid Rev 01 dated 14/02/2014'.

पावर सेक्टर- पश्चिमी क्षेत्र Power Sector-Western Region
श्रीमोहिनी कॉम्प्लेक्स, 345 किंग्सवे, नागपुर Shreemohini complex, 345 Kingsway Nagpur - 440 001
फोन / Phone 0712- 3048600, फैक्स FAX: 0712- 3048699 www.bhelpswr.co.in

Ref: BHE/PW/PUR/MADT1-STR U-3 & U-4/1212-1213/Corrigendum 02

Date 15/02/2014

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-02 (Pre Bid Meeting-1212-13)" against NIT-16367 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)

Enclosures:

1. GA Drawings two Nos as file titled 'GA Drawings 1212-13'
2. Revised Volume II Price Bid as file titled 'Voll II Price Bid rev 01 dated 14/2/2014'