

BHEL PAN: AAACB4146P

Ref: BHE/PW/PUR/ MANUT-BAL ESP U # 1&2/2170/Corr-03

Date: 03/09/2019

-----Page 1 of 2-----

To

ALL BIDDERS,

**Sub: Corrigendum-03: Issue of clarification**

**Job:** COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO SITE; ERECTION , TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ELECTRO STATIC PRECIPITATOR , DUCT SUPPORTING STRUCTURE, DUCTS AND DAMPERS FROM ESP OUTLET FUNNEL TO CHIMNEY, INSULATION, FINAL PAINTING ETC OF 4x270 MW MANUGURU THERMAL POWER PROJECT AT 4X270 MW MANUGURU TPS TSGENCO, MANUGURU, DISTT. - KHAMMAM, TELANGANA.

E- TENDER SPECIFICATION NUMBER: BHE/PW/PUR/ MANUT-BAL ESP U # 1&2/2170

Bidders to kindly take note of the following:

**AA) ISSUE OF CLARIFICATIONS:**

SI No	CLAUSE NO	EXISTING PROVISION	Bidder's query	BHEL's Clarification
1	APPENDIX II	PAINTING SCHEME	In the Painitng Scheme it is provided that the floor grills needs to painted in Black Colour. We presume that, generally the floor grills are galvanized and it does not required any painting. Please clarify.	Painting only if required shall be done by bidder
2	13.2	Neutralization pit for EDTA cleaning is to be made by the Contractor. After completion of job pit has to be dismantled and area is to be leveled before handing over of area to owner.Effluent to be disposed off safely from neutralizing pit to a safe area as per instruction of BHEL Engineer.	AS the Chemical Cleaning Process is not in Contractor Scope, this Point should be removed from the contract	This is an inadvertent error and the same is not in contractor scope.

SI No	CLAUSE NO	EXISTING PROVISION	Bidder's query	BHEL's Clarification
3	7	For the convenience of bidders, BHEL has issued an excel sheet with all the requisite formulae as described above. However the referred excel sheet shall not form part of contract document. Further, this sheet should not be uploaded at the e-Portal.	The quantities provided in the excel sheet, the Weightage factor sheet (Chapter XIX of TCC) and the Weight details provided in the TCC are not matching. The Weight details provided for one ESP has the whole weight of the ESP, not the weight of the balance works quantity. Please clarify.	Weight details given in TCC is for one ESP however the balance work is as per Chapter- XIX: Weightage/ Factor of Vol- I TCC

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → [www.bhel.abcprocure.com](http://www.bhel.abcprocure.com)

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,

Yours faithfully,

AGM (Purchase)