



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-25-Jun-18

CORRIGENDUM- 03

PROJECT	:	2X490 MW NTPC DADRI STAGE-II-FGD SYSTEM
PACKAGE	:	HVAC for FGD
ENQUIRY NO	:	E-5948/2018 Dated 22.05.2018
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

In reference to the above mentioned tender enquiry for **HVAC for FGD** package

Please note the following.

1. Due date is extended from **25-Jun-18** to **2-Jul-18** till **02:00 PM**. Bid opening shall be done at 03:00 PM on the due date
2. Price Format has been revised due to changes in Annexure-I of Price format (refer s.no C7). Latest price format is attached.
3. Pre-bid Queries Clarification

S.No	SECTION/CLAUSE /PAGE NO.	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED	BHEL REPLIES
1.	Sl.No 9 (b) in Price Schedule	3TR Machine - 240 V, 1 Phase	As per All manufacturer standard, 3TR Machines are 3 Phase only	Noted, for 3 TR capacity 3 phase or single phase power supply shall be provided as per the OEM requirement
2.	Local Control Panel for AC & Ventilation	As per Electrical scope same in M/s. BHEL Scope	Kindly specify the panel in bidder's scope or not?	As per the Electrical scope split sheet local push button station (for motors) is in BHEL scope. however local control panel is in bidders scope only

Bidders who have submitted their offer may revise their bid accordingly.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Upendra Chaudhary
Dy. Manager