

Ref: BHE/PW/PUR/WNT2-CVL PKG-1 (Leveling & Grading)/1331/Corrigendum 03

Date 24/10/2014

To

ALL BIDDERS

Sub: Corrigendum-03: Issue of Clarification & amendment.

JOB: Complete Leveling, grading, Land development, & Slope Protection including Excavation, Backfilling, filling with burrowed soil, disposal of unserviceable earth and all associated works, complete as per specification of entire Plant Area AT WTPS 1X800MW UNIT-8WANAKBORI, GUJRAT.

Tender Specification Number : BHE/PW/PUR/WNT2-CVL PKG-1 (Leveling & Grading)/1331

Bidders to kindly take note of the following:

AA) Clarification to the Queries of Bidder

SI No	Description / Bidder's query	BHEL's clarification
1	Refer Item No 14 of 'Volume II Price Bid Specification': Furnish the details of Non-Woven Geo Textile	The Properties of Non woven geo textile shall meet the following requirement a) thickness = 2mm (minimum) b) Weight = 250 gm/sqm (minimum) c) Material = Polypropylene d) Tensile Strength = 16 kN/m (minimum) e) CBR Puncture strength = 2900 N (minimum) f) Width to be supplied = 1.8m (minimum)
2	Refer item no. In item No.11, concrete, quantity taken is 3792 CUM and In item No.12 providing and fixing form work, qty.10379 sqm is taken. However In Drawing Nowhere it is mentioned that in what type of structure this item is to be executed	Concreting as per item no.11 &12 are required to be laid over Geo textile/mortar in the slope/flat portion of fill/cut. The formwork is for placing the concrete.

BB) Amendment to Price bid specification

Refer item no.11 of Vol II price bid, the item description is hereby amended & to be read as given below;

Item no.	Existing description as per price bid	Amended as
11	Concrete of grade M-10 as levelling course below finished floor level, under and around foundations/floors, drains, pits, sumps, encasing guard stones etc at all levels complete.	Providing and laying PCC of nominal mix 1:3:6 as lean concrete, levelling course, mud mat under and around foundations/floors at any depth below finished floor level etc.

The price bid shall be evaluated by considering the above amendment.

Ref: BHE/PW/PUR/WNT2-CVL PKG-1 (Leveling & Grading)/1331/Corrigendum 03

Date 24/10/2014

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-03 (against NIT-19770 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)