

Ref.: BHE/PW/PUR/WNT2-MMS/1341/Corrigendum 03
To

DT: 04/11/2014

ALL BIDDERS

Sub: Issue of Corrigendum for issue of tender spec & extension of offer submission date

Job: PROVIDING SERVICES FOR MATERIAL HANDLING & MATERIALS MANAGEMENT FOR 800 MW GSECL WANAKBORI PROJECT AT GSECL WANAKBORI.

T.S.No: BHE/PW/PUR/WNT2-MMS/1341

Bidders to kindly take note of the following:

=====

AA) Issue of Project details:-

The encrypted chapter-I 'Project Information' of vol I A Technical conditions of contract is re issued herewith for bidder's reference.

BB) Extension of due date for offer submission

**The due date of offer submission has been extended to 13/11/2014, 15.00 HRS.
Technical Bid shall be opened on 13/11/2014 at 16.00 hrs.**

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-03" against NIT-19974 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)

Encl: Chapter - I

	Project Information
1.1	<u>LOCATION AND APPROACH:</u> Location : Wanakbori, District-Kheda, Gujarat Nearest Railway Station : Sevaliya (8KM) – Anand-Godhra main line Nearest Airport : Vadodara (85 KM from site), Ahmedabad (100 KM from site) Nearest Sea Port : Kandla Access By Road : 10KM from Dakor-Godhra NH No. 8, 02 KM from Balasinor-Sevaliya SH No. 59 Major Towns/Cities: 13 KM from Balasinor and 10KM from sevaliya. Land: Within existing Thermal Power Station. North-East side of the existing plot. Source Of Coal: Indian coal sourced from captive mines Machha in Talchar, Orissa. Source Of Water: River Mahi, flowing by side of existing Wanakbori Power Station.
1.2	CLIMATIC CONDITIONS: 1) Maximum ambient Temperature: 40.8 degree Centigrade 2) Minimum ambient Temperature: 10.8 degree Centigrade 3) Seismic Zone : Part 3, Zone-III as per IS:1893/84 4) Relative Humidity: 81.5 % 5) Wind Speed: 39m/sec