

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/RGIT-STR/727/Corrigendum-03

Date 19/05/2010

-----Page 1 of 2-----

To

ALL BIDDERS

Sub: Corrigendum-03 Clarification & Amendment to Tender Specification.

JOB: SUPPLY (EXCEPTING BHEL SUPPLIED MATERIALS), COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO FABRICATION YARD/ SITE; FABRICATION, ERECTION, ALIGNMENT, BOLTING/ WELDING/ FASTENING, GROUTING, TESTING AND HANDING OVER OF **BUNKER STRUCTURE** AND RAW COAL BUNKER IN BLOCK-I (UNIT-1 & 3) AND BLOCK-II (UNIT-2 & 4) AT **4X600 MW RAIGARH THERMAL POWER PROJECT AT JINDAL POWER LIMITED PHASE-III,(4X600 MW JPL STPP)** SALIBHATA,TAMNAR VILLAGE ,DISTT: RAIGARH, CHATTISGARH

Tender Specification No: BHE/PW/PUR/RGIT- STR/727

Bidders to kindly take note of the following clarification & amendment which will be part of tender specification:

=====

1-Que by bidder) In rate schedule of ST NO:2301, G.I HANDRAIL word should be deleted from item description & it shall be separate item head like supply of electroforged gratings of item no.ST 2307.

Clarification by BHEL--Since quantity of railing is very negligible comparing to total structural quantity, separation of railing item is not required .However BHEL will supply GI pipes of required diameter for Hand railing.

2-Que by bidder) In rate schedule of ST 2307 of electroforged gratings supply of permanent grade C M.S. BOLTS & NUTS shall be paid separately in item no. 2309. In this rate schedule Inadvertently it is typed as 2309 (i).Pl. rectify the same.

Clarification by BHEL : It is confirmed that, in rate schedule of ST 2307 of electroforged gratings supply of permanent grade C M.S. BOLTS & NUTS shall be paid separately in item no. 2309 .

3-Que by bidder) Pl. confirm that in labour hutment M/S BHEL will supply adequate power on chargeable basis.

Clarification by BHEL - Contractor has to make his own arrangement for required supply of power for labour hutment .BHEL will not be able to supply. For further details please refer clause 5.1 for this.

B) Refer Section-12 , Cl No – 12.1of technical bid- Vol- I - PAYMENT TERMS has been amended as below

12.1 STAGES OF PROGRESSIVE PRO-RATA PAYMENTS

12.1.1) 100% OF ITEM RATE ON PRORATA BASIS AGAINST MONTHLY RA BILLS AS FOLLOWS.

-----Page 2 of 2-----

12.1.2) Item no-2301 (a) FABRICATION

For item no 2301(a) payment terms will be as follows:

- i) 85% on completion of fabrication
- ii) 15% on completion of blasting and one coat of primer

12.1.3) AS PER SCHEDULE OF RATE FOR ITEM NO. 2301 (b) FOR ERECTION, ALIGNMENT & WELDING CAN BE FURTHER BREAK UP AS FOLLOWS

- i) ERECTION : 80% OF QUOTED RATE UNDER ITEM 2301 (b)
- ii) WELDING & ALIGNMENT : BALANCE 20% OF QUOTED RATE UNDER ITEM 2301(b)

12.1.4) For item no-2306

For item no 2306 payment terms will be as follows:

- (a) 35% Epoxy resin based paint pigmented with Titanium dioxide with min DFT of 100 microns over one coat of primer after completion of erection.
- (b) 35% Topcoat of epoxy paint suitably pigmented of approved shade with glossy finish and DFT of 75 microns
- (c) 30% Finish coat of Polyurethane of minimum DFT of 250 microns

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-03 (Clarificaton727)" against NIT-8092 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,
Yours faithfully,

SR. MANAGER (Purchase)