

OPEN TENDER FOR STATION LIGHTING SSTEM OF 2X660 MW ENNORE SEZ STPP

Ref No. : E-4882/2015/CORRIGENDUM/04

Date: 22.07.2015

CORRIGENDUM/ ADDENDUM-4

Subject: Corrigenda to Technical specification no. PE-TS-412-507-E001

Ref: Our Tender Enquiry No. E-4882/2015 dated 05.06.2015 for STATION LIGHTING SYSTEM for 2X660MW ENNORE SEZ STPP

This is in reference to the subject Tender Enquiry please note following:

1. *Technical Clarification (Refer enclosed Annexure-II)*

Thanking You,

With Regards,

For & on behalf of BHEL

Raj 22/07/15
Rajeev Kumar

Sr.Engineer/PG-II-2

Enclosure:-

1. ANNEXURE-II

Please reply to:

Rajeev Kumar (Sr.Engr/PG-II-2)

Power Project Engineering Institute Building

HRD & ESI Complex Plot No. 25, Sector -16 A,

BHEL-PEM,Noida-201301 (U.P.)

Tel No. 0120-4213582

ANNEXURE-II

Sr.No	QUERIES dt 21.7.15			PEM-ELEC REPLY dt 22.7.15
	Please note that the specifications for following items are not provided in tender documents of Ennore Station Lighting package. We request you kindly provide us detailed technical specifications for below items.			
7.5	Receptacle - Type RD	Nos.	3	Receptacle- Type RD, 125A, 415V, 3phase. Other requirements shall be same as Receptacle- Type RC
3.29	100W Marine type luminaire with lamp	Nos.	2	To follow technical specification