

Ref.: BHE/PW/PUR/ MANUT-CWP/1505 & 1511 /Corrigendum 04

DT: 25/09/2015

To

ALL BIDDERS

Sub: Issue of Corrigendum 04 for issue of Clarification & time extension for offer submission

Job: COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO SITE, ERECTION, TESTING & COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF CW PIPING, INCLUDING BUTTER FLY VALVES, FITTINGS, HANGERS, SUPPORTS ETC & WRAPPING & COATING WITH 4 MM TAPE AS PER IS STANDURDS, FINAL PAINTING (INCLUDING SUPPLY OF PAINT, WRAPPING & COATING) ETC. FOR BLOCK I (UNIT 1 & 2) AND BLOCK II (UNIT 3 &4) OF 4X270 MW MANUGURU THERMAL POWER PROJECT.

T.S.No: BHE/PW/PUR/ MANUT-CWP BLOCK I/1505 & BHE/PW/PUR/ MANUT-CWP BLOCK II/1511

Bidders to kindly take note of the following:

=====

A) Clarification to Bidder's Queries

<u>Sl No</u>	<u>Clause Reference</u>	<u>Bidder's Query</u>	<u>BHEL's Clarifications</u>
1	<u>APPENDIX 1</u> <u>LIST OF APPLICABLE</u> <u>PGMA's. OF VOL IA</u> <u>TCC</u>	Please Confirm the Weight of Hangers & Supports of PGMA 80-923 is not given in the table	Weight detail is not available exclusively for this package. Agency has to erect these materials, as issued by BHEL, as per scope of work on tonnage basis. Payment will be on tonnage basis.
2	Annexure I , Vol I A TCC	What is the length of Pipe Dia. 600 for ACW System?	Length detail is not available. Agency has to erect these materials, as issued by BHEL, as per drawing on tonnage basis. Payment will be on tonnage basis.
3	Chapter XIII (WELDING, RADIOGRAPHY AND OTHER NON-DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT)	Please provide the approved vendor list for the Welding Electrodes and filler wires	Agency shall submit the list of Welding Electrodes and filler wires manufacturer & obtain the prior approval for manufacturer by BHEL before supply. Bidder can refer the approved list of BHEL- Trichy/ PC for reference.

Ref.: BHE/PW/PUR/ MANUT-CWP/1505 & 1511 /Corrigendum 04

DT: 25/09/2015

4	Chapter XVI Painting	Please provide the Detailed Painting Schedule which includes the Paint Film Thickness, Paint Details, Painting Area etc.	Please refer the Drawing of Plant water system-P& ID attached with Vol I A TCC.
5		Please provide the approved Vendor List for Paints	Agency shall submit the list of Paint manufacturer & obtain the prior approval for manufacturer by BHEL before supply.

B) Extension of due date for offer submission

The due date of offer submission has been extended to 01/10/2015, 15.00 HRS. Technical Bid shall be opened on 01/10/2015 at 16.00 hrs.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-04" against NIT-23539 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)