

Ref: BHE/PW/PUR/DHLI-STG/1198/Corrigendum 04

Date : 30/12/2013

To

ALL BIDDERS

JOB: RECEIPT OF MATERIALS FROM STORES, TRANSPORTATION TO SITE OF WORK, ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF STEAM TURBINE, TURBO-GENERATOR, CONDENSER, TG INTEGRAL PIPING, HP & LP HEATERS, DEAERATOR, WITH ASSOCIATED EQUIPMENTS/TANKS/VESSELS, FST & DEAERATOR, LP BYPASS SYSTEM WITH ASSOCIATED PLATFORM, POWER CYCLE PUMPS & ASSOCIATED AUXILIARIES B.F. VALVES , BOUGHT OUT ITEMS ETC IN 1 & 2 OF 2x150 MW AT SINTEX INFRA PROJECT LTD, WAGHODE, SHINDKHEDA , MAHARASHTRA

Tender Specification Number: BHE/PW/PUR/DHLI-STG/1198

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

Sl.No	Bidder's query	BHEL's clarification
1.	Refer Clause 9.11 of TCC, Page No. 50: The Interconnecting piping between HP Valve & HP Overload valves which is of pipe size approx. Dia.168.3x18.3 tk. mm, Material specification-P91 & about 32 Nos. (Tentative) site weld joints are specifically included under the scope of work of this specification. W.r.t above, Please clarify whether the required Induction heating machine, welding electrodes, filler wire for P-91 welding are in the scope of Contractor or not?	Induction heating machine, Welding electrodes & filler wire for P-91 welding for work mentioned in clause 9.11 (as per contract) will be provided by BHEL.
2.	Refer Clause 16.1 of TCC, page no. 77: It has stated that Generator stator will be lifted by tandem operation with 02 No of EOT Cranes provided by BHEL/Customer and other arrangements/T&P/attachments including Lifting Slings for lifting & placement of Generator Stator shall be provided by contractor as scope of work Please clarify about issue of lifting beam which required for tandem operation.	Lifting beam which required for tandem operation of stator while lifting will be arranged by BHEL.

BB) Issue of Amendment

Refer Vol I A, Page no.52 ,Chapter –X 'Specific Exclusions' of Technical Conditions of Contract' . As per Sl no.K , the Final Painting is excluded from scope of work. However the same clause has been amended as 'void ' . The Final painting including supply of paints will be in scope of Contractor. Payment against Painting shall be made as per payment terms (Chapter VII) given in TCC,Vol IA.

CC) PERCENTAGE IMPACT ON QUOTED PRICE:

Consequent upon the Clarifications & Amendment issued in AA & BB above, bidders may submit the 'Percentage Impact' either Positive or Negative on the quoted price (if found necessary) for E & C o STG & auxl in the format given below:

Ref: BHE/PW/PUR/DHLI-STG/1198/Corrigendum 04

Date : 30/12/2013

S.N.	DESCRIPTION	(%)Percentage Impact (Positive or Negative) on Quoted Price
1	<u>Lump sum Price as quoted for entire E & C works of One Unit of 150 MW STG Set</u>	PLUS % (IN FIGURES)
		PLUS PERCENT (IN WORDS)
		OR
		MINUS % (IN FIGURES)
		MINUS PERCENT (IN WORDS)
		OR, NO CHANGE

Bidders may kindly note that the Percentage Impact shall be applied to the "Lumpsum Price for entire E & C works of **One Unit of 150 MW STG set & Auxl**" quoted in the price bid and final value shall be rounded off. In case any bidder fills up more than one option, then BHEL will consider the option offering lower cost to BHEL.

The filled up format is to be submitted to us duly signed by your authorized representative, along with your official seal in a sealed envelope on or before **15.00 Hrs of 02/01/2014**, failing which the price quoted in original Sealed Price Bid will be considered for evaluation.

DD) TIME EXTENSION FOR OFFER SUBMISSION

THE DUE DATE & TIME OF OFFER SUBMISSION IS HEREBY EXTENDED TO 02/01/2014,15.00 HRS.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-04 (Clarification-1198)" against NIT-15749 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)