



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-14-Aug-20

CORRIGENDUM- 04

PROJECTs	:	4 X 210 MW NTPC Kahalgaon- R&M (ESP)
PACKAGE	:	HVAC SYSTEM FOR R&M PROJECTS
ENQUIRY NO	:	PE/PG/NTK/E-6475/2020 Dated 16.07.2020
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

Bidders are requested to go through the following changes

1. Due date for bid submission has extended from 14-Aug-20 to 21-Aug-20 till 10:00 AM. Bid opening shall be done at 02:00 PM on the due date.
2. Refer attached technical amendment -2.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP

	HVACSYSTEM 4X210 MW KAHALGAON-R&M	SPECIFICATION NO. PE-TS-455- 571-13000A-A001	
		AMMENDMENT-2	
		DATE: 13.08.2020	
		Page 1 of 1	
AMENDMENT#2 TO EXISTING CLAUSES OF TECHNICAL SPECIFICATION			
Sl. No.	Clause	Existing description	To be read as (Amendment)
1.	Sub Section C1 & Section I, Clause : 5, Page 10 of 277	The Package A/C unit shall have one condenser (outdoor) unit and one Evaporator (indoor) unit to suit the control rooms. The capacity (TR) of the indoor unit shall be the actual capacity (100%) as the package units are intended to be used.	The Package A/C unit shall have one or multiple condenser (outdoor) unit and one Evaporator (indoor) unit to suit the control rooms. The capacity (TR) of the indoor unit shall be the actual capacity (100%) as the package units are intended to be used.
			