

Heavy Electrica dia Undertaking) Western Region,

y, Nagpur - 440 001 48600-604 FAX:-0712- 3048605/3048698/3048699

Inlimited Pages and Expanded Features

To

ALL BIDDERS

SUB: Clarification and Extension of last date (GSEG HAZIRA - CONSTRUCTION POWER PACKAGE)

JOB: PROVIDING CONSTRUCTION POWER SYSTEM ON "BOO BASIS (BUILD OWN OPERATE) / LEASE BASIS, OF 6.6/0.433 KV POWER DISTRIBUTION NETWORK, CONSISTING OF TRANSFORMERS, ASSOCIATED EQUIPMENT AND HT/LT CABLING ETC.FOR CONCTRUCTION WORKS OF 1x 350 MW (FIRST PHASE OF 1050 MW) COMBINED CYCLE POWER PLANT AT GUJARAT STATE ENERGY GENERATION LIMITED NEAR HAZIRA, VILLAGE MORA, POST BHATHA, SURAT HAZIRA ROAD, DISTRICT -SURAT, PIN: 394510 (GUJARAT)

TS NO: BHE/PW/PUR/GSEG HAZIRA-CPS/588

Please refer Tender Specification for the subject job detailed above. All bidders are requested to take note of the following

AA) CLARIFICATIONS TO THE QUERIES

QUERY 1: 415V ACDB SLD shows two incomers & one Bus Coupler, but in detail specification SI no 4.7.2 page 21 to 57 only one coupler is indicated. Please clarify the requirement of incomers and bus Couplers

CLARIFICATION TO QUERY 1: Bidder should provide the 415 Volt ACDB as detailed in SLD. There are two incomer & one bus coupler . The rating of incomer (input from 6.6/0.433 KV ,1250 KVA transformer & Bus coupler should be selected considering the full load current on LT side of transformer + safety margin . For Second incomer for (DG set 250 KVA) , rating should be according the full load current of DG set + safety margin.

QUERY 2: Transformer HT side termination: Refer SI No 16, 4.7.1. clarify the requirement, ACSR conductor or cable box termination.

<u>CLARIFICATION TO QUERY 2:</u> Termination on HT /LT side of Transformer should be with cable box, accordingly transformer should be provided with cable box arrangement. The size of HT & LT cable should meet the fault level.

QUERY 3: Refer 4.7.2. Clarify the requirement. 20KA or 50KA LT board fault level.

CLARIFICATION TO QUERY 3: Fault level of 40 KA is sufficient for 415 Volt ACDB.



Click Here to upgrade to Unlimited Pages and Expanded Features

Thank you for using PDF Complete.

Heavy Electricals Limited dia Undertaking)
Western Region,
N, Napur - 440 001
48600-604 FAX:-0712-3048605/3048698/3048699

Ref: BHE/PW/PUR/GSEG HAZIRA -CPS/588/Corrigendum-07 Date: 11/08/2008
QUERY 4: Refer Sl No. 203 & 2.7. Clarify the requirement for secondary side, cable or bus duct CLARIFICATION TO QUERY 4: Same as mentioned in clarification to query 2.
BB) PRICE IMPACT
Consequent upon above clarifications, bidders who have submitted their offers are requested to submit their price impact IN A SEALED ENVELOP in the format attached. (This format is also uploaded in BHEL Web page as file titled "Price Impact-588")
CC) EXTENSION OF LAST DATE
The last date for submission of Tender has been re-scheduled to 18/08/2008, 16.00 hrs. Technical Bid shall be opened on 18/08/2008 at 17.30 hrs
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.
Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidders unqualified acceptance of this corrigendum.
This letter is hosted as file titled %Corrigendum-07 (Clarification and time extn-588)+ against NIT-4880 in BHEL web page (www.bhel.com Tender Notifications View Corrigendum).
Thanking you, Yours faithfully,
DGM (Purchase)