



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-27-Aug-20

CORRIGENDUM- 07

PROJECTs	:	4 X 210 MW NTPC Kahalgaon- R&M (ESP)
PACKAGE	:	HVAC SYSTEM FOR R&M PROJECTS
ENQUIRY NO	:	PE/PG/NTK/E-6475/2020 Dated 16.07.2020
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

Bidders are requested to go through the following changes

1. Kindly refer below pre-bid clarifications.

S.No	Pre-bid Queries	BHEL Reply to Pre-bid Queries
I.	Please send details/explanation of GIU based control system leaving no ambiguity	Kindly note that GIU is a Graphical User Interface with field equipment's. It is a small microprocessor based system & shall be used to control various HVAC equipment like Package AC, Heaters, humidifier, Fresh Air Fan and other items/instruments as per process scheme. This shall be as per manufacturer's standard practice.
II.	We understand that the given AC units are package units with actual capacity of 15 TR & 5 TR respectively at 43.3 deg. C ambient. These are not ductable split AC units. For example, we have 22 TR, 16.5/17 TR, 5.5 TR, 8.5 TR etc. Package Units as also ductable split AC. Here in scope are package units with outdoor unit (air-cooled condensers) & indoor unit with compressor, whereas ductable split AC has outdoor (air cooled condensing unit with compressor) & indoor unit. Confirmation is sought only to have enhanced clarity	Capacity of PAC mentioned in Tender Specification / Price format is 15TR and 5TR actual capacity. Bidder to ensure that nominal capacity of PAC selected by them is adequate to meet minimum requirement of 15TR and 5TR PAC. Compressor shall be indoor unit for Air cooled Package AC as already mentioned in the Amendment No.-1.



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

2. Due date for bid submission has extended from 27-Aug-20 to 01-Sep-20 till 10:00 AM. Bid opening shall be done at 02:00 PM on the due date.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP

Corrigendum