



Bharat Heavy Electricals Limited

(A Govt. of India Undertaking)

Material Management, 10th Floor, Plot No.C-20/1A/1, Joy Tower,
Sector-62, Noida, Uttar Pradesh, PIN No: 201301

Phone: 0120-6748541, Fax: 0120-6748550, Email: vineet.gupta@bhel.in

CORRIGENDUM - 11 TO NIT NO-63589

Subject: Corrigendum-11 to Tender enquiry for Pre-bid Tie up for Supply & Services of 400/220 kV GIS for POWERGRID Navsari Project.

Project : POWERGRID Navsari PROJECT
Equipment / Item : SUPPLY & SERVICES OF 400/220 kV GIS.
Enquiry No/Date : NIT 63589_61G2200250 dated 05.03.2022
BHEL NIT NO : 63589
Original Tender due date : 09.03.2022

This Corrigendum is being issued by BHEL TBG against above mentioned NIT/ enquiry **to issued Technical corrigendum-03 & extend due date for offer submission up to 11:00 AM on 12.04.2022 and bids shall be opened 04:00 PM onwards on 12.04.2022**

All other terms and conditions for this tender enquiry shall remain unchanged.

Bidder to ensure submission of offer on or before due.

Note: Tender ID in CPP Portal is **2022_BHEL_9147_2**.

Thanking you

Vineet Gupta
BHEL TBG, NOIDA

S No.	VOLUME/SECTION/CLAUSE	VOLUME/SECTION/CLAUSE AS EXISTING	VOLUME/SECTION/CLAUSE AS AMENDED/ADDED
1.	Clause No. 10 (xx) (Specific Requirement) of Section-Project (Rev-00) of Technical Specification	New Clause added	<p>New Clause no. 15.4 of Section-GIS (Rev-05A) of Technical Specification</p> <p>15.4 Alternatively, Contractor can offer the above functionalities in a control IEDs/SGCs meeting all the above requirement. However, in such case, emergency trip for CB to be provided separately and SGC/Local control IED shall be provided with display indicating SLD of the bay.</p>

OTHER POINTS / CLARIFICATIONS

S. No.	Volume/Section/ Clause No.	Description	Bidder's Query	POWERGRID Reply
2	Section-GIS, Rev-05A of Technical Specification	LOCAL CONTROL CUBICLE (LCC)	As Merging unit (MU), SGC IED is part of LCC, we don't need Annunciator for the local indication.	Bidder to refer Sl. No. 1 above
3	Section-GIS, Rev-05A of Technical Specification	LOCAL CONTROL CUBICLE (LCC)	LCC shall be provided with IP42 only, hence supplied IED shall be flush mounted type	Bidder to comply the requirement of Technical specifications as per the provisions of bidding documents.
4	Section-GIS, Rev-05A of Technical Specification	LOCAL CONTROL CUBICLE (LCC)	As IED will behave as Switch gear controller, local controls switch of conventional methods can be removed	Bidder to refer Sl. No. 1 above

NOTE: ALL TECHNICAL CLARIFICATION(S) FOR GIS, PUBLISHED BY M/S POWERGRID WITH REFERENCE TO SUBJECT PROJECT SHALL BE DEEMED VALID FOR THIS TECHNICAL SPECIFICATION