



**BHARAT HEAVY ELECTRICALS LIMITED**  
**PROJECT ENGINEERING MANAGEMENT, NOIDA**

Date-19-Nov-20

**CORRIGENDUM- 15**

|                   |          |                                                 |
|-------------------|----------|-------------------------------------------------|
| <b>PROJECTs</b>   | <b>:</b> | <b>4 X 210 MW NTPC Kahalgaon- R&amp;M (ESP)</b> |
| <b>PACKAGE</b>    | <b>:</b> | <b>HVAC SYSTEM FOR R&amp;M PROJECTS</b>         |
| <b>ENQUIRY NO</b> | <b>:</b> | <b>PE/PG/NTK/E-6475/2020 Dated 16.07.2020</b>   |
| <b>SUBJECT</b>    | <b>:</b> | <b>DUE DATE EXTENSION</b>                       |

| Type of Corrigendum     |                                     |                          |                                     |
|-------------------------|-------------------------------------|--------------------------|-------------------------------------|
| Technical Corrigendum - | <input checked="" type="checkbox"/> | Commercial Corrigendum - | <input checked="" type="checkbox"/> |

Bidders are requested to go through the following changes

1. Due date for bid submission has extended from 19-Nov-20 to 01-Dec-20 till 10:00 AM. Bid opening shall be done at 02:00 PM on the due date.
2. Financial PQR has been revised and attached.
3. Replies to pre-bid queries

| Bidder Queries                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     | BHEL Replies                                             |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
| 1. We take reference of Clause No.4.03.02(SI No 8) (Pages 22 & 23 of 277) wherein the location of Fine (Microvee filters) is specified as at the discharge of each individual AHU.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Fine filter is not required for Ductable split AC units. |
| 2. Point No 21 of Amendment -3 of 26 10 20 (Page 6 of 7) - Corrigendum 14 of 29.10.20 states the following:<br>" wherever AHU is mentioned in the specification the same shall be read as Ductable AC"<br><br>Kindly confirm if we have to provide Fine (Microvee) filters for the Ductable split units. Also please note that in case the microvee filters have to be introduced , suitably designed Booster fan to be added in the circuit to overcome the static pressure caused by the Fine filters as the evaporating unit blower of Ductable split units which are meant for commercial applications ,are not designed to accommodate the static caused by the fine filters. |                                                          |

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra  
Manager/BOP



## PRE - QUALIFYING REQUIREMENTS

**Rev-01**

|             |                                       |
|-------------|---------------------------------------|
| ENQUIRY NO: | PE/PG/NTK/E-6475/2020 Date 16.07.2020 |
| PROJECT:    | 4 X 210 MW NTPC KAHALGAON R&M         |
| PACKAGE:    | HVAC SYSTEM                           |

### CRITERIA FOR EVALUATION - FINANCIAL :

|                                                                                                 |                                    |
|-------------------------------------------------------------------------------------------------|------------------------------------|
| Average annual financial turnover during the last Three Financial Years should not be less than | Amount (in Rs.)<br>Rs.22,00,000.00 |
| Rupees Twenty Two Lakh(s) Only                                                                  |                                    |

#### Notes:-

a) The bidder has to submit financial accounts (audited, if applicable comprising of Audit report, Balance Sheet, Profit & Loss A/c Statement and Notes/Schedules pertaining to Turnover/Sales/Revenue), for last three years (or from the date of incorporation, whichever is less) as on tender due date to review the above criteria. In case the incorporation of vendor is less than 3 years, average annual financial turnover shall be calculated based on available information as below:-

i) If the accounts are available for  $\leq 1$  Financial Year, the Average Annual Turnover shall be calculated based on available information divided by 1 (One).

ii) If the accounts are available for  $>1$  but  $\leq 2$  Financial Years, the Average Annual Turnover shall be calculated based on available information divided by 2 (Two).

iii) If the accounts are available for  $>2$  but  $\leq 3$  Financial Years, the Average Annual Turnover shall be calculated based on available information divided by 3 (Three).

b) Foreign bidder is to submit a latest report from reputed third party business rating agency like Dun & Bradstreet, Credit reform etc. in addition to the documents mentioned at point (a) above for review of above criteria.

c) Other Income shall not be considered for arriving at Annual Turnover/Sales. For evaluation purpose, Turnover figure excluding taxes shall be considered.

d) For evaluation of foreign bidder, exchange rate (TT selling rate of SBI) as on scheduled date of tender opening (Part-I bid in case of two part bid) shall be considered.