

CORRIGENDUM-1

Tender Enquiry R/5599/2017/2049V1 Dt: 19/08/2017 for the item 'Continuous Ambient Air Quality Monitoring System' for 370 MW Yelahanka CCPP site.

With reference to above tender enquiry following changes has been made, kindly quote accordingly:-

- (1) Display of analyzer output at one location of the said plant is required, for that purpose kindly quote in your offer as per the specification attached for "Continuous Ambient Air Quality Monitoring System – Electronic Board" – 01 no.
- (2) The last date of submission of the offer has extended from 09/09/2017 (01:45 pm) to 23/09/2017 (01:45 pm)
- (3) The Enquiry opening date has extended from 09/09/2017 (02:00 pm) to 23/09/2017 (02:00 pm)

G Singh
08/09/2017
(Gurdeep Singh)
Dy. Engineer (PPX-BOI)

Shailendra Kumar, Sr. Manager (PPX-BOI)

Shailendra Kumar
08/09/17

Continuous Ambient Air Quality Monitoring System-Electronic Display Board

1.0 Application: Electronic Display Board to be provided for AAQMS station.

1.1 Electronic Display Board Specification:

A LED display board to display the parameters of the AAQMS from central station with specification as below:

- Type : LED display
- No. of Lines : 02 Lines
- Size : 1 feet x 6 feet
- Enclosure : IP-65
- Visibility : 100m during daytime
- Interfacing of centralized AAQMS DAS with electronic display board through suitable wireless communication link (GSM modem), necessary Hardware and Software for the same is also to be included.

2.0 Quality Assurance: Test certificate for the Electronic Display Board should be supplied along with the equipment.

3.1 The Vendor should give the Compliance sheet of the quoted items as per the specifications.

3.2. Guarantee: The equipment shall be guaranteed for a period of 18 months from the date of dispatch or 12 months from the date of Installation & Commissioning, whichever is earlier.

Failing to comply with the Guarantee clause the offer will be rejected straightway.

Mam
7/9/17

Associate
7/9/17
(Dr. S. Bhatnagar)
SDGM (PCRI)