



BHARAT HEAVY ELECTRICALS LIMITED
HEEP: HARDWAR-249 403 (UA)
Fax: 01334-226084/226462, Phone: 01334-284175
E-mail: manojy@bhelhwr.co.in

BHEL Enquiry No. : B/4222/1/1139V/2

Date of issue : 20/09/2012

Due Date : 18/10/2012

Corrigendum-1

Tender no.: B/4222/1/1139V/2

Item Description: Condenser Air Evacuation Package

Following corrigendum is being issued:

DESIGN DATA FOR THE REQUIREMENT OF CONDENSER AIR EVACUATION PACKAGE OF TENDER ENQUIRY NO B/4222/1/1139V/2 SHALL BE CONSIDERED AS UNDER:

- 1) COOLING WATER DESIGN INLET TEMP. = 33 DEG C
- 2) CONDENSER DESIGN BACK PRESSURE = 0.1033 ATA
- 3) WATER QUALITY= NORMAL WATER

IN CASE OF ANY CONTRADICTION, REQUIREMENT OF ANNEXURE NO. 31611770003 REV 01 SHOULD BE TREATED AS FINAL (THIS ANNEXURE HAS ALREADY BEEN AVAILABLE AT OUR WEBSITE.

Thanking you,
Yours faithfully,

For and on behalf of BHEL Haridwar

(Manoj Kumar)
Sr. Engineer (PPX-BOI)