

4X270 MW BHADRADRI TPP**MILL REJECT HANDLING SYSTEM: CORRIGENDUM-1 TO TECH. SPEC. PE-TS-411-160-A001**

S.N.	VOLUME/SECTION/ CLAUSE NO.	Deletion	Addition
1	VOLUME IIB, SECTION C, Annexure-II, Page no. 242, Mandatory spares list	<u>Mechanical</u>	
		NIL	Pt no V : LP piping valves & traps (complete assembly) - 5% or min. 1 no. (whichever is more) for each size, type & rating for total population
2		<u>Control & Instrumentation</u>	
		3. Pressure switches -1 pc of each type 4. Level switches -1 pc of each type	3. Local gauges/ Switch (for Pressure, DP, Temperature, Flow, level, etc.) (10% of total number of instruments offered for each model and type for the project or a minimum of one number, whichever is more.) – 2 lot 4. Push buttons, electrical control switches and Illuminated push buttons etc (20% of installed) – 2 lot