



Bharat Heavy Electricals Limited
Transmission Business Group
Materials Management
Tower-A, 5th floor, Advant Navis Business Park
Plot No. 7, Sector-142, Expressway Noida-201305
Telephone : 0120-6748464
E-mail : vineet.gupta@bhel.in

SUBJECT- Corrigendum-1

DATE 12.10.2016

- | | | | |
|----|--------------------|---|--------------------------|
| 1. | Project | : | TSGENCO Kothagudem |
| 2. | Equipment / Item | : | Fire Protection system |
| 3. | Enquiry No. / Date | : | 346E159 Rev.0 _NIT 29496 |

With reference to the above NIT, Corrigendum to Technical Specification is attached.

Password to unlock the **"Price bid/un price bid for Indian Suppliers"** is **6143334**. Qty. and unit for Line item no. 1 i.e. "Hydrant System" is to be considered as "1 Lot" i.e. Qty. shall be "1" and Unit shall be "Lot".

Bidders may unlock the above both sheets with password and fill up the sheet as required as per tender terms and conditions.

Quotation Formats to be uploaded by bidders shall be same as provided by BHEL on bheleps.buyjunction.in otherwise Bids shall be liable for rejection.

All other terms and conditions of tender shall remain same. Kindly ensure to submit your offer as due.

(Vineet Gupta)
Sr. Engineer- TBMM



CLIENT – TELANGANA STATE POWER GENERATION COMPANY
CONSULTANT- DEVELOPMENT CONSULTANTS PVT. LTD
PROJECT: 1 x 800 MW KOTHAGUDAM TPS - 400 KV SWITCHYARD
CORRIGENDUM TO TECHNICAL SPECIFICATION FOR FIREFIGHTING SYSTEM

TB-377-552-031/A

Rev. 0

Page | 1

CORRIGENDUM TO TECHNICAL SPECIFICATION - FPS.

Ref. Cl. No. 3.3.2, II, q) Pg. 9 of 19, Section – 1 of Technical Specification (TB-377-552-031, Rev.0)

– This clause of TS calls for Non-electrically operated fiber optic LHS cable for detection in MVW spray system. Requirement mentioned in the aforesaid clause shall be considered as final by the bidders.

Ref. Cl. No. 3.1, g), Pg. 3 of 19, Section – 1 of Technical Specification (TB-377-552-031, Rev.0) –
Specification of LHS mentioned here stands deleted.