



Bharat Heavy Electricals Limited
Material Management Division,
Transmission Business Group,
5th Floor, Advant Navis IT Business Park,
Plot No. 7, Sector-142, Expressway Noida, Noida-201305
Distt. Gautam Budh Nagar (U.P.)
Phones: 0120-6748487

Subject- Corrigendum-3

DATE: 19.07.2018

1. Project : TANTRANSCO ARIYALUR
2. Equipment / Item : 765kV CLAMPS AND CONNECTORS
3. Enquiry No. / Date : 278E095 , Dtd. 04-06-2018

With reference to the above tenders, kindly note the following;

(1) Corrigendum for clarification on technical specification as per Annexure

All other conditions shall remain same.

Bhagchand Kumawat
Sr. Mgr (TBMM)

CORRIGENDUM-3

Project:TANTRANSCO ARIYALUR

Equipment / Item:765kV CLAMPS AND CONNECTORS

Enquiry No. / Date:278E095; date:04-06-2018

Technical specification doc. No. TB-394-316-131, Rev -00

Sl. NO.	Reference cl. of technical specification	Requirements as per technical specification rev - 00	Technical specification Amendment
1.	Sl. No. 10.(c) of cl. No. 1.2 of section-1	For connecting GI- Galvanised mild steel shield wire	This clause is not applicable
2.	Sl. No. 10.(e) of cl. No. 1.2 of section-1	Spring washers for items 'a' to 'c'- Electro galvanised mild steel suitable for at least service conditions-3 as per IS:1573	This clause is not applicable
3.	(1) Sl. no. (iii) of Annexure-2(page 1 of 5) (2)Sl. no. 42. (iii) of Annexure-2(page 2 of 5)	The connector shall be designed for minimum 120 % of the maximum current carrying capacity of the conductor.	The current rating of connectors shall be as per BHEL tender BOQ specification (i.e. as per Annexure-1A and Annexure-1B).
4.	Sl. no. 4.14 (Vi) of Annexure-2(page 3 of 5)	Flexible connector if used shall be made from tinned copper	It can be either tinned flexible copper or AAAC conductor
5.	cl. no. 2.5.2 of section -2	All Bolts and nuts shall be of stainless steel conforming to ISS 1570-304	All Bolts and nuts shall be hot dip galvanised mild steel

Note - All other technical parameters of technical specification doc. No. TB-394-316-131, Rev -00 shall remain unchanged.

