

PRE BID REPLY/CORRIGENDUM-5 DT 12.09.2020

PROJETCS: Natural gas firing provision in GTG 1 & GTG 2 of MRPL CPP-3 Unit

END USER : MRPL

Ref. No. : T7B1T34280 (Fine Filter Skids)

SR. NO.	DRG/Doc . NO.	Clasue No.	As Published	Clarification
1	Annexure-II	--		Only Quick opening closure equal to full vessel diameter (of filter) shall be provided, to meet the process and maintenance requirements. Revised Annexure-II rev01 is attached. Bidder to follow revised document. Accordingly, Annexure -II provided earlier stands null.
2	Sub Vendor List	--		All the miscellaneous items which are not figuring in Annexure XVI-R01 shall be sourced from reputed make after obtaining approval from BHEL.

All other terms & conditions of the tender will remain unchanged.

Bidders are requested to submit a copy of this corrigendum (as part of technical bid) duly signed by the authorized signatory & stamped with official seal as a token of Bidder's unqualified acceptance to this corrigendum no.3.