

Corrigendum - 7 to Tender for the work of “Construction of One (1) No. 275 M Tall Single Flue RCC Chimney complete in all respect including Chimney Raft, Chimney RCC wind shield, Fabrication & Erection of Steel Flue Cans, Structural Platforms etc., Installation of Electrical items in conformity with the approved layout, Elevators etc. to complete the Chimney in all respect for 1x800 MW Deen Bandhu Chhotu Ram Thermal Power Plant, HPGCL, Yamunanagar, Haryana”.

A) Some of the Bidders had asked queries in the published tender specification. The clarifications issued by BHEL are furnished below:

| Sl. No. | Reference clause of Tender  | Existing Clause   | Bidder's Query  | BHEL's Response  |
|---------|---|---|---|--|
| 1.      | BOQ item no. 35 Providing & installing, at all levels, resin bonded rock wool insulation slab ..... Qty – 100 sqm | Cl. 12.6 on page 462 & 463 of Volume 4 – Tender Specification – Insulation reads as follows - <i>“Insulation for the exposed portion of flue at the top shall consist of 6 layers of insulation material .... minimum density of 200 kg/cum. <b>This shall be protected from the elements by means of a Stainless Steel Cladding, flashing &amp; hood of grade 316 L stainless steel.</b></i><br><br>Further, Cl. 12.8.1 – reads as follows – <i>The insulation... .. <b>This shall be protected from the elements by wrapping with 3 mm thk Titanium / C-276 sheet cladding.</b></i> | As per Cl. 12.6 of technical specn., Insulation material <b><i>shall be protected from the elements by means of a Stainless-Steel Cladding, flashing &amp; hood of grade 316 L stainless steel.</i></b> However, <b>the description of BOQ item does not mention any type of cladding material.</b> Hence, we understand that <b>the cost of cladding of insulation material with Stainless steel or any other material is not included in the rate</b> of this BOQ item. Further, Cladding of insulation material (if any in scope of work of this tender) shall be paid separately under another similar BOQ items such as A26(ix) / 31(a)/etc. <b>Please confirm/clarify the same.</b> | As per the BOQ item, Galvanised wire netting along with the required fixing accessories is to be provided over the insulation material. Stainless sheet cladding, if required shall be paid separately under BOQ item no. A26(ix). |
| 2.      | BOQ item no. A35 Providing & installing, at all levels, resin bonded rock wool insulation of semi-rigid resin     | Cl. 12.6 on page 462 & 463 of Volume 4 – Tender Specification – Insulation reads as follows - <i>“Insulation for the exposed portion of flue at the top shall consist of 6 layers of insulation material .... minimum density of 200 kg/cum. <b>This shall be protected from the elements by means of a Stainless Steel Cladding, flashing &amp; hood of grade 316 L stainless steel.</b></i>   | As per Cl. 12.6 of technical specn., Insulation material <b><i>shall be protected from the elements by means of a Stainless Steel Cladding, flashing &amp; hood of grade 316 L stainless steel.</i></b> However, <b>the description of BOQ item does not mention any type of cladding material.</b> Hence, we understand that <b>the cost of cladding of insulation material with Stainless steel or any other material is not included in the rate</b> of this BOQ item. Further, Cladding of insulation material (if any in scope of work of this tender) shall be paid   | As per the BOQ item, Galvanised wire netting along with the required fixing accessories is to be provided over the insulation material. Stainless sheet cladding, if required shall be paid  |

| Sl. No. | Reference clause of Tender                                  | Existing Clause   | Bidder's Query  | BHEL's Response                        |
|---------|---|---|---|--|
|         | bonded type, in the form of slab<br>..... Qty<br>- 6100 sqm | Further, Cl. 12.8.1 – reads as follows – <i>The insulation... ..</i> <b><i>This shall be protected from the elements by wrapping with 3 mm thk Titanium / C-276 sheet cladding.</i></b> | separately under another similar BOQ items such as A26(ix) / 31(a)/etc. <b>Please confirm/clarify the same.</b> | separately under BOQ item no. A26(ix). |

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

for BHARAT HEAVY ELECTRICALS LTD  
Sr. Manager / SCT- CPC