

CORRIGENDUM

Package Name: Cable Trays and Accessories

Indent Ref No : IS-1-17-2001/034 dated 21.03.2022

Project Name : 1x660MW PANKI TPS

Technical Clarification / Amendment

Sr. No.	BID Query	Clarification / Amendment
1	What is the Radius of horizontal & Vertical bends and Tee & Cross Joints to be considered by the bidder.	Bidder to consider the 600mm radius ('R) for horizontal & Vertical bends and Tee & Cross Joints of various cable tray widths (i.e., 600mm & 300mm)