



Corrigendum-1 to GEM/2025/B/6179560 dtd. 29-04-2025

Item	: Tender for supply 400kV & below rating Isolators for PGCIL Projects
NIC Tender ID	: GEM/2025/B/6179560 dtd. 29-04-2025
BHEL NIT Ref. No.	: NIT_90796
Enquiry	: Open Tender (Through GeM)

The due date & time for Bid Submission and Technical Bid Opening are extended as below:

Bid Submission Date & Time	: 21.05.2025, 14:00 Hrs. IST
Technical Bid Opening Date & Time	: 21.05.2025, 14:30 Hrs. IST

1. Revised ATC Clause No. 10 Guarantee Clause: -

The contractor shall guarantee that the equipment being supplied under this contract shall be new and of first quality workmanship and equipment / material supplied and services rendered (if applicable) shall be guaranteed to be free from all defects and faults in design & engineering, material, workmanship & manufacture and in full conformity with the Purchase Order / Contract, Technical Specifications & approved drawings / data sheets, if any, for 400kV & Below rating Isolators - for 18 months from the date of last delivery OR Twelve (12) months from the date of Taking Over/Completion of Facilities*, whichever is later.

*Taking over / Completion of facility: For purpose of guarantee, date of taking over/ completion of facilities is fixed as

- 08.06.2026 for Mandsaur (New) & Indore (extn)
- 26.10.2026 for Kurawar (New), Sujalpur (extn) & Ashtha (extn)
- 30.11.2026 for Barmer (New) & Fatehgarh-III (extn)

The defective equipment / material / component shall be replaced free of cost at site. Freight & Insurance during transit shall also be in the scope of the supplier / contractor. Notification of any transit damage will be sent by BHEL to supplier within 15 days from date of receipt of material at site. Any expenditure for dismantling and re-erection of the replaced equipment / material / component shall be to supplier's / contractor's account. All replacements during the guarantee period shall be delivered at site promptly and satisfactorily within the reasonable period mutually agreed between BHEL and supplier. In the event of the supplier / contractor failing to replace the defective equipment / material / component within the time period mentioned above, the same shall be considered as breach of the contract and BHEL may proceed as per provision mentioned in this NIT without prejudice to any other rights under the contract.

In the event of the supplier / contractor failing to replace the defective equipment / material / component within the time period mentioned above, the same shall be considered as breach of the contract and BHEL may proceed as per provision mentioned in this NIT without prejudice to any other rights under the contract.

2. Duration of ePBG required (in Months) :- 30 Months

3. 145 kV 1250 A without Earth Switch Tandem Type Isolator: To be considered above isolator as **Mechanically ganged as per Unpriced Bid (Sl.No.11) , and Clause 6 a), Section -2 of Technical Specification**

All other terms & conditions of the NIT shall remain unchanged.

-Sd-

For and on behalf of BHEL
Ved Prakash Meena
Sr. Manager, TBMM
BHEL TBG Noida
Phone no. 120-6748462
Email Id: ved@bhel.in