

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037 for the work of “DRY BOTTOM ASH HANDLING SYSTEM-EPC PACKAGE (PACKAGE-I) OF UNIT#3 & UNIT#4 at 2x800 MW DVC Koderma Ph-II, Jharkhand.”

A) Modification in TECHNICAL CONDITIONS OF CONTRACT (TCC): The following clause of existing TCC are revised as below;

Sl. No.	TCC Reference Clause No. / Annexure	Existing clause in Tender	Revised clause
1	–	General	Please find DVC Amendment No 9 to bid specification (Enclosed with this Corrigendum-I)
2	TCC, Annexure-15	A.2 Dry Bottom Ash Secondary Crushers (as applicable)	A.2 Dry Bottom Ash Secondary Crushers
3	TCC, Annexure-15	Remarks of A.2 – Please confirm the secondary crusher is applicable or not	Remarks of A.2- Shall be consider as null and void.
4	TCC, Annexure-15	Note – Bidder to note that the guaranteed power consumption for Ash Handling System shall not exceed 350 KW.	Note – Bidder to note that the guaranteed power consumption for Dry Bottom Ash Handling System shall not exceed 350 KW.

B) Some of the Bidders had asked queries in the published tender specification. The clarifications issued by BHEL are as below;

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
1	2-TCC-Volume-IA/ 02.23.00	INSURANCE: - Owner (DVC) and BHEL shall be as co-insured under all insurance policies taken out by the Contractor....	The request to co-insure BHEL and DVC (<i>Section 02.23.00 TCC</i>) must be subject to the consent of the Contractor's insurer	Tender conditions prevail

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
2	2-TCC-Volume-IA/ 13.09.00	Guarantee/ Warrantee/ Defect Liability period If the Facilities or any part thereof cannot be used by reason of such defect and/or making good of such defect, the Defect Liability Period of the Facilities or such part, as the case may be, shall be extended by a period equal to the period during which the Facilities or such part cannot be used by the Owner because of any of the aforesaid reasons	There is no need to extend the defect liability period (18 months from completion or 12 months from acceptance) by periods the Facilities or any part cannot be used due to remedial actions etc. (Section 13.09.00 TCC), since the defect liability period for any repaired or renewed part will anyway be extended by 12 months.	Tender conditions prevail
3	2-TCC-Volume-IA/ 13.09.00	Guarantee/ Warrantee/ Defect Liability period	A latest period for any revolving warranty period of 30 months from completion or 24 months from acceptance should be added.	Tender conditions prevail
4	2-TCC-Volume-IA/ 13.10.00	Latent defects Liability The contractor's liability for latent defects warranty shall be limited to a period of five (5) years from the end of Defect Liability Period.	The period for latent defects from the end of the defect liability period (Section 13.10.00 TCC) should be two years	Tender conditions prevail
5	2-TCC-Volume-IA/ 16.01.00	iii. Technology Transfer Agreement (as applicable) The technology transfer agreement shall cover transfer of technological know-how for Dry Bottom Ash Handling System in the form of complete transfer of design dossier, design software's, drawings and documentation, quality system manuals and imparting relevant personnel training to the Indian Manufacturing Company.	Rather than “a complete transfer of design dossier, design software’s, drawings” etc. according to Section 16.01.00 TCC, the technology transfer should be limited to an irrevocable license in connection with a utilization of the technology for the purpose of the project.	Tender conditions prevail
6	2-TCC-Volume-IA/ 17.01.00 2-TCC-Volume-IA/ 17.02.00	LD for delay in successful completion of Facilities (excluding Mandatory Spares) LIQUIDATED DAMAGES/PENALTIES FOR SHORTFALL IN GUARANTEED PERFORMANCE PARAMETERS	The LD regulations for delay (Section 17.01.00 TCC) and non-achievement of the performance parameters (Section 17.02.00 TCC) should only be applicable, if the delay or non-achievement “is attributable to the Contractor”.	The tender condition is clear, Bidder to also refer Force Majeure conditions in GCC.

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
7	2-TCC-Volume-IA/ 17.01.00 2-TCC-Volume-IA/ 17.02.00		Also, LDs should be the sole remedy available to BHEL for the corresponding default.	Tender conditions prevail
8	2-TCC-Volume-IA/ 17.01.00 2-TCC-Volume-IA/ 17.02.00		The LDs for late delivery should not be related to the full contract value, but just to the portion of the delayed deliveries.	Tender conditions prevail
9	3-GCC-Volume-IC/2.15	Rejection The Supplier / Vendor/ Contractor shall intimate the BHEL in writing, within 15 days after the receipt of rejection advice, regarding disposal of the rejected plant/ equipment/ material /stores. If no advice is received within aforesaid period the BHEL shall be at liberty to return the stores at the cost of the Supplier/ Vendor/ Contractor after recovering the cost, if any paid by the BHEL including inward freight and other incidental charges. The BHEL will not be responsible for rejected stores thereafter and no claim whatsoever will rest on the BHEL	A rejection right of BHEL according to Section 2.15 GCC should only apply in case of a material default, which cannot be remedied within a reasonable period, and which deprives the Owner from the use or the benefits of the deliveries	Tender conditions prevail

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
10	3-GCC-Volume-IC/2.23	INDEMNIFICATION Indemnity Bond	An indemnity according to Section 2.23 GCC and the annexed Indemnity Bond should just apply to third party claims against BHEL and only in case of the Contractor's default. Also, the indemnity must be subject to the limitation of liability to the Contract value and under exclusion of any indirect or consequential damages. Unlimited liabilities for any breach of contract or breach of law (as stipulated in the Indemnity Bond) are not acceptable - only in cases of IP violations, breach of confidentiality, willful misconduct and personal injury.	Tender conditions prevail

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
11	3-GCC-Volume-IC/2.25	LIMITATION ON LIABILITY: Notwithstanding anything to the contrary in this Contract or LOA or Work Order or Purchase Order or any other mutually agreed document between the parties, the maximum liability, for damages, of the Supplier / Vendor / Contractor, its servants or agents, shall under no circumstances exceed an amount equal to the Price of the Contract or the Work Order or Purchase Order. Neither party shall be liable to the other for any indirect or consequential loss or damage, including but not limited to loss of use, loss of profits, or loss of contracts, or special, punitive, exemplary losses whatsoever, arising out of or in connection with this contract. This shall not be applicable on the recoveries made by Customer from BHEL on account of Supplier / Vendor / Contractor, any other type of recoveries for workmanship, material, T&P etc. due from the contractor.	The limitation of liability clause (Section 2.25 GCC) should clarify that the maximum aggregate liability of Contractor shall apply to “all kinds of damages, including LDs and indemnities in connection with the Contract and under law, irrespective of the legal ground and also in case of rejection or termination of the Contract.”	Tender conditions prevail

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
12	3-GCC-Volume-IC/2.26.1	If the completion of work as detailed in the scope of work gets delayed beyond the contract period, the contractor shall request for an extension of the contract and BHEL at its discretion may extend the Contract. If the completion of work gets delayed for reasons not attributable to the contractor, the contract period may be suitably extended at the sole discretion of BHEL. Pending finalization of extension of time, payment to vendors for supply/E&C executed during such periods will be done only in excess of maximum LD amount as per LD clause for delayed delivery. On finalization of extension of time, payments to vendor shall be regularized in line with approved time extension proposal.	The Contractor's entitlement to adjustments of the time schedule and additional expenses should not be subject to BHEL's discretion (Section 2.26.1 GCC), but should be applicable in case of defaults and/or delays not attributable to the Contractor.	Tender conditions prevail
13	3-GCC-Volume-IC/2.32.1	SETTLEMENT OF DISPUTES	In case of disputes between the parties (Section 2.32.1 GCC), each party shall appoint one arbitrator, and they nominate the head of a panel consisting of three arbitrators.	Tender conditions prevail
14	3-GCC-Volume-IC/2.35.1	To withdraw any portion of work/supply and/or to restrict/alter quantum of work/supply as indicated in the contract during the progress of work and get it done through other agencies/vendors/suppliers/Contractors to fulfil BHEL's commitment to its customer or the date of completion is advanced due to other emergent reasons/ BHEL's obligation to its customer.	Only with the Contractor's consent and upon compensation of the applicable costs and expenses (unless there is any termination or rejection right under the Contract) BHEL shall be entitled to withdraw portions of the Contractor's scope and award them to other suppliers (Section 2.35.1 GCC).	Tender conditions prevail

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
15	3-GCC-Volume-IC/2.35.2	BREACH OF CONTRACT AND REMEDIES:	BHEL's termination right for breach of contract, which will not be remedied within 14 days (Section 2.35.2 GCC) should be limited to material defaults that cannot be remedied by the Contractor, despite numerous attempts, and only to the affected scope.	Tender conditions prevail
16	3-GCC-Volume-IC/2.35.2		A termination right with regard to the full Contract should just become applicable, if the Owner is substantially deprived from the use or the benefits of the deliveries.	Tender conditions prevail
17	3-GCC-Volume-IC/2.35.2.2	Remedies in case of Breach of Contract: ii). Upon termination of contract, BHEL shall be entitled to recover an amount equivalent to 10% of the Contract Value for the damages on account of breach of contract committed by the Contractor. This amount shall be recovered by way of encashing the security instruments like performance bank guarantee etc available with BHEL against the said contract. In case the value of the security instruments available is less than 10% of the contract value, the balance amount shall be recovered from other financial remedies (i.e. available bills of the contractor, retention amount, from the money due to the Contractor etc. with BHEL) or the other legal remedies shall be pursued.	In case of termination, no penalty of 10% of the Contract shall apply (Section 2.35.2.2 GCC).	Tender conditions prevail
18	3-GCC-Volume-IC/2.20	Successful bidder awarded the contract should deposit performance security of 5% of Contract value or as mentioned in TCC, towards fulfilment of all contractual obligations, including warranty obligations	We propose waiver of CPBG for MSME.	Tender conditions prevail

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
19	(TCC)- CHAPTER-XV: PAYMENT TERMS: Clause 15.01.01	Three percent (3%) of the basic price for supply of plant & equipment against submission of basic/ detail Engineering drawings/ documents on pro rata basis against submission of equivalent amount of Bank Guarantee as per BHEL format. The pro rata payment shall be as per the list of drawings enclosed under Annexure-31 to Technical Specifications of the tender and the weightage against each drawing/ document thereon shall be finalized subsequently after award of Contract.	Five percent (5%) of the basic price for supply of plant & equipment against submission of basic/ detail Engineering drawings/ documents on pro rata basis against submission of equivalent amount of Bank Guarantee as per BHEL format. The pro rata payment shall be as per the list of drawings enclosed under Annexure-31 to Technical Specifications of the tender and the weightage against each drawing/ document thereon shall be finalized subsequently after award of Contract.	Tender condition prevails
20	(TCC)- CHAPTER-XV: PAYMENT TERMS: Clause 15.01.02	Two Percent (2%) of the basic price for supply of plant & equipment against customer approval (CATI) of basic/ detail Engineering drawings/ documents on pro rata basis against submission of equivalent amount of Bank Guarantee as per BHEL format. The pro rata payment shall be as per the list of drawings enclosed under Annexure-31 to Technical Specifications of the tender and the weightage against each drawing/ document thereon shall be finalized subsequently after award of Contract.	Five Percent (5%) of the basic price for supply of plant & equipment against customer approval (CATI) of basic/ detail Engineering drawings/ documents on pro rata basis against submission of equivalent amount of Bank Guarantee as per BHEL format. The pro rata payment shall be as per the list of drawings enclosed under Annexure-31 to Technical Specifications of the tender and the weightage against each drawing/ document thereon shall be finalized subsequently after award of Contract	Tender condition prevails
21	(TCC)- CHAPTER-XV: PAYMENT TERMS: Clause 15.01.03	a. 3% of Total Ex-Works Supply Price Component of Supply of Plant & equipment on Submission of copy of purchase order placed by Contractor and duly accepted by Sub-Contractor(s) for Dry Bottom Ash Crusher against submission of equivalent amount of Bank Guarantee as per BHEL format.	5% of Total Ex-Works Supply Price Component of Supply of Plant & equipment on Submission of copy of purchase order placed by Contractor and duly accepted by Sub-Contractor(s) for Dry Bottom Ash Crusher against submission of equivalent amount of Bank Guarantee as per BHEL format.	Tender condition prevails

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
22		b. 2% of Total Ex-Works Supply Price Component of Supply of plant & equipment on Submission of copy of purchase order placed by Contractor and duly accepted by Sub-Contractor(s) for Belt/Chain Conveyor. against submission of equivalent amount of Bank Guarantee as per BHEL format.	5% of Total Ex-Works Supply Price Component of Supply of plant & equipment on Submission of copy of purchase order placed by Contractor and duly accepted by Sub-Contractor(s) for Belt/Chain Conveyor. against submission of equivalent amount of Bank Guarantee as per BHEL format.	Tender condition prevails
23		c. 3% of Total Ex-Works Supply Price Component of Supply of plant & equipment on Site Mobilization and completion of storage facilities at site as per the certification of Construction Manager against submission of equivalent amount of Bank Guarantee as per BHEL format.	0% of Total Ex-Works Supply Price Component of Supply of plant & equipment on Site Mobilization and completion of storage facilities at site as per the certification of Construction Manager against submission of equivalent amount of Bank Guarantee as per BHEL format. Since there are already separate payment terms for site services, the linkage of supply payment to site activities is not required.	Tender condition prevails
24		d. 2% of Total Ex-Works Supply Price Component of plant & equipment on Finalization of Erection agency, i.e., Submission of copy of purchase order placed by Contractor and duly accepted by Sub-Contractor(s) for Erection agency against submission of equivalent amount of Bank Guarantee as per BHEL format.	0% of Total Ex-Works Supply Price Component of plant & equipment on Finalization of Erection agency, i.e., Submission of copy of purchase order placed by Contractor and duly accepted by Sub-Contractor(s) for Erection agency against submission of equivalent amount of Bank Guarantee as per BHEL format. Since there are already separate payment terms for site services, the linkage of supply payment to site activities is not required.	Tender condition prevails

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
25		Sixty (60%) of Total Ex-Works Supply Price Component of the Contract Price for each identified equipment upon dispatch of equipment from manufacturer's works on pro-rata basis on production of invoices and satisfactory evidence of shipment (which shall be original Goods Receipt or receipted GR/Rail receipt) including Material Dispatch Clearance Certificate (MDCC).	60% of Total Ex-Works Supply Price Component of the Contract Price for each identified equipment upon dispatch of equipment from manufacturer's works on pro-rata basis on production of invoices and satisfactory evidence of shipment (which shall be original Goods Receipt or receipted GR/Rail receipt) including Material Dispatch Clearance Certificate (MDCC).	Tender condition prevails
26			a) The total bank guarantee against clauses 15.01.01, 15.01.02 and 15.01.03 shall be 20% which shall be given after receipt of PO and value of Bank Guarantee shall be reduced correspondingly to completion of above-mentioned milestones. b) Bank Guarantee shall be valid up to completion of last milestone linked to BG.	a) Tender conditions prevail. b) The BG shall be valid up to completion of supplies.
27	2-TCC-Volume-IA/15.01.05	Two percent (2%) of Ex-Works Supply Price Component of the contract price on Successful Completion of Trial/Initial Operation including all associated auxiliaries and ancillary works for Unit-3 and certification by the owner/customer/ BHEL.	One percent (1%) of Ex-Works Supply Price Component of the contract price on Successful Completion of Trial/Initial Operation including all associated auxiliaries and ancillary works for Unit-3 and certification by the owner/customer/ BHEL. If trial/initial operation is delayed for more than 06 months beyond the original schedule for reasons not attributable to contractor, then 1% amount shall be released based on submission of bank guarantee of equivalent amount valid for 01 year plus 01 month claim period.	Tender conditions prevail.

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
28	2-TCC-Volume-IA/15.01.06	Two percent (2%) of Ex-Works Supply Price Component of the contract price on Successful Completion of applicable Performance Guarantee Tests for Unit-3, to be conducted along with Trial/Initial operation as specified in Technical Specifications and issuance of Completion Certificate for Unit-3 and certification by owner/customer/ BHEL.	One Percent (1%) of Ex-Works Supply Price Component of the contract price on Successful Completion of applicable Performance Guarantee Tests for Unit-3, to be conducted along with Trial/Initial operation as specified in Technical Specifications and issuance of Completion Certificate for Unit-3 and certification by owner/customer/ BHEL. If performance guarantee test is delayed for more than 06 months beyond the original schedule for reasons not attributable to contractor, then 1% amount shall be released based on submission of bank guarantee of equivalent amount valid for 01 year plus 01-month claim period.	Tender conditions prevail.
29	2-TCC-Volume-IA/15.01.07	One percent (1%) of Ex-Works Supply Price Component of the contract price on successful completion of applicable Performance Guarantee Tests to be conducted after Trial/Initial operations as specified in Technical Specifications and issue of Operational Acceptance Certificate for Unit-3. However, if for reasons not attributable to contractor, in case the performance Guarantee (PG) Test of the Facilities or the relevant part thereof to be conducted after Trial/Initial operations cannot be successfully completed within the period of one year from the due date of completion of such PG test(s), then aforesaid 1%amount shall be released upon submission of Bank Guarantee of equivalent value. Such BG shall be released after successful conductance of PG test.	Half Percent (0.5%) of Ex-Works Supply Price Component of the contract price on successful completion of applicable Performance Guarantee Tests to be conducted after Trial/Initial operations as specified in Technical Specifications and issue of Operational Acceptance Certificate for Unit-3. If operation acceptance certificate is delayed for more than 06 months beyond the original schedule for reasons not attributable to contractor, then 0.5% amount shall be released based on submission of bank guarantee of equivalent amount valid for 01 year plus 01-month claim period.	Tender conditions prevail.

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
30	2-TCC-Volume-IA/15.01.08	Two percent (2%) of Ex-Works Supply Price Component of the contract price on Successful Completion of Trial/Initial Operation including all associated auxiliaries and ancillary works for Unit-4 and certification by the owner/customer/ BHEL.	One percent (1%) of Ex-Works Supply Price Component of the contract price on Successful Completion of Trial/Initial Operation including all associated auxiliaries and ancillary works for Unit-4 and certification by the owner/customer/ BHEL. If trial/initial operation is delayed for more than 06 months beyond the original schedule for reasons not attributable to contractor, then 1% amount shall be released based on submission of bank guarantee of equivalent amount valid for 01 year plus 01-month claim period.	Tender conditions prevail.
31	2-TCC-Volume-IA/15.01.09	Two Percent (2%) of Ex-Works Supply Price Component of the contract price on Successful Completion of applicable Performance Guarantee Tests for Unit-4, to be conducted along with Trial/Initial operation as specified in Technical Specifications and issuance of Completion Certificate for Unit-4 and certification by owner/customer/ BHEL.	One Percent (1%) of Ex-Works Supply Price Component of the contract price on Successful Completion of applicable Performance Guarantee Tests for Unit-4, to be conducted along with Trial/Initial operation as specified in Technical Specifications and issuance of Completion Certificate for Unit-4 and certification by owner/customer/ BHEL. If performance guarantee test is delayed for more than 06 months beyond the original schedule for reasons not attributable to contractor, then 1% amount shall be released based on submission of bank guarantee of equivalent amount valid for 01 year plus 01-month claim period.	Tender conditions prevail.

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
32	2-TCC-Volume-IA/15.01.10	One Percent (1%) of Ex-Works Supply Price Component of the contract price on successful completion of applicable Performance Guarantee Tests to be conducted after Trial/Initial operations as specified in Technical Specifications and issue of Operational Acceptance Certificate for Unit-4. However, if for reasons not attributable to contractor, in case the performance Guarantee (PG) Test of the Facilities or the relevant part thereof to be conducted after Trial/Initial operations cannot be successfully completed within the period of one year from the due date of completion of such PG test(s), then aforesaid 1% amount shall be released upon submission of Bank Guarantee of equivalent value. Such BG shall be released after successful conductance of PG test.	Half Percent (0.5%) of Ex-Works Supply Price Component of the contract price on successful completion of applicable Performance Guarantee Tests to be conducted after Trial/Initial operations as specified in Technical Specifications and issue of Operational Acceptance Certificate for Unit-4. If operation acceptance certificate is delayed for more than 06 months beyond the original schedule for reasons not attributable to contractor, then 0.5% amount shall be released based on submission of bank guarantee of equivalent amount valid for 01 year plus 01-month claim period.	Tender conditions prevail.
33	2-TCC-Volume-IA/ 15.12.01	Retention Amount shall be 5% of contract value and shall be furnished before the first RA Bill becomes due for payment.	We request waiver of retention amount of 5% of contract value as already there is certain supply payment linked to retention milestones such as trial operation, PG test, Operation acceptance certificate.	Tender conditions prevail.
34	2-TCC-Volume-IA/ 15.12.01(iv)	Bank Guarantee from Scheduled Banks/ Public Financial Institutions as defined in the Companies Act and in line with GCC	Retention BG (if required) shall be split into unit wise.	Tender conditions prevail.
35	Government eProcurement System Portal/ EMD Fee Details	EMD Exemption Allowed - NO	Please note that as per clause no. 4.0 of NIT it has been mentioned that for Micro and Small Enterprises (MSEs) or Startups as recognized by Department for Promotion of Industry and Internal Trade (DPIIT) shall be exempted from payment of EMD.	For Micro and Small Enterprises (MSEs) or Startups as recognized by Department for Promotion of Industry and Internal Trade (DPIIT) shall be exempted from payment of EMD.

Corrigendum - I dated 09/07/2026 to CPC Tender No. BHEL/CPC/KOD/EPC DBA/27/037

Sl. No.	Section/ Clause No	Specification/ Existing Provision	Bidder's Query	BHEL Clarification
36	2-TCC-Volume-IA/ clause no. 03.02.00 / Broad System Description 2-TCC-ANNEXURE-7-Part6 / Amendments 07 Koderma TPS Ph-II Scope change proposal	The ash particle output size from the secondary crusher below BA intermediate silo shall be (-) 25 mm. PERFORMANCE GUARANTEE PARAMETERS 7. Secondary crusher capacity (without ECO Ash-As Applicable): 108 TPH and designed particle output size (-) 25 mm (min. 90% of BA Particle)	Please confirm that if the primary crusher will achieve the designed Particle output size (-) 25 mm (min. 90% of BA Particle) then in that case secondary crusher is not required	Secondary Crusher is required as per NIT specification. Bidder to follow the same.
37	2-TCC-Annexure-7- DVC Clarification and- Amendments- Part5; Annexure I Clause: 9.01.00 2-TCC-Annexure-7-DVC- Clarification-and- Amendments-Part6/Bid Clarification-1 Lot-3/S.N.1	Heat resistant stainless steel as per standard and proven practice of OEM. Material of conveyor to be provided is specified in technical specification. However, any other superior type of material of conveyor shall be provided as recommended by BAHS supplier based on their proven design and to be finalized during detail engineering.	Since the Technology and construction of dry bottom ash system is specific to OEM, we request to modify the same as "Heat resistant steel as per standard and proven practice of OEM". Please confirm OR, Alternatively, Alloy Structure steel 15CrMo may please be permitted as conveyor pan material. Please confirm. Please note that 15CrMo is proven MOC for similar capacity projects (141 TPH) conveyor pan material and has been used in our several installations. We guarantee performance of the system with 15CrMo material.	Bidder is requested to refer DVC amendment No. 9 to bid specification (Enclosed with this corrigendum-I).

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

Enclosed:

- a) DVC Amendment No 9 to bid specification.

**for BHARAT HEAVY ELECTRICALS LTD
Manager/ Purchase**

DVC-KTPH PH-II (2x800MW) EPC PACKAGE CHANGE PROPOSAL

AMENDMENT NO. 9 TO BID SPECIFICATION

S. NO.	SPECIFICATION REFERENCE				EXISTING (As per Base Specification)				SHALL BE READ AS			
	SEC/ PART	SUB- SEC.	PAGE NO.	CLAUSE NO.								
1.	VI/B	Annexure -I (A- 21 AHP Scope Change)	7 of 22	9.01.00: Material of construction of conveyor components								
					(a)	conveyor	:	Heat resistant stainless steel as per standard and proven practice of OEM.	(a)	conveyor	:	Heat resistant stainless steel/ 15CrMo as per standard and proven practice of OEM.
					(b)	casing	:	Carbon steel	(b)	casing	:	Carbon steel