

परियोजना
इंजीनियरिंग
प्रबंधन

Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)

Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)



CORRIGENDUM-II

Ref: PE/PG/RTC/ E-5598/2017 dtd 24/04/2017

Date: 09/05/2017

SUBJECT: Rate Contract of Plate Heat Exchanger (Bid Due date: 17/05/2017; 02:00 PM)

To,

This is in reference to our Tender Enquiry no. PE/PG/RTC/ E-5598/2017 dtd 24/04/2017 for the subject package. In this connection, bidders may please note that Corrigendum-II is being issued as per enclosed annexure-I, which will be part of NIT.

All other terms remains unaltered.

Thanking you.
Yours faithfully,
For and on behalf of BHEL

(N C SHARMA)
Sr. Engineer/ MM

09/05/17



कृपया प्रेषित करें :	Please reply to :	फ़ोन Phone No:
बीएचईएल, पीएस-पीईएम	BHEL, PS-PEM,	91-120 - 4213591
पीपीआई भवन	PPEI Building,	Fax No.
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	0120-4329045
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचईएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA

AMENDMENT NO. 2

**TECHNICAL SPECIFICATION
FOR
RATE CONTRACT
OF
PLATE HEAT EXCHANGERS**

**Specification No. : PE-TS-RC-179-N001 (REV. 0)
Vol II B**



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**

	TECHNICAL SPECIFICATION FOR RATE CONTRACT OF PLATE HEAT EXCHANGERS	SPECN. NO.:	PE-TS-RC-179-N001		
	AMENDMENT NO. 2	REV. NO.	0	DATE:	09.05.17

- 1.0 With reference to **PHE Type IV, Datasheet A, Section IB** (page No. 8 to 44 of pdf file) of Technical Specification, please consider the Specification amended as below:

Cl. No	Clauses as mentioned in Technical Specification	Amended Clauses
1.6	Connection Pipe Size of Secondary Side = 350 NB	Connection Pipe Size of Secondary Side = 450 NB
3.1	Flow Rate (ACW Side) = 750 M ³ /Hr	Flow Rate (ACW Side) = 1200 M ³ /Hr
3.2	Inlet Temperature (DMCW Side) = 47.0 Deg C	Inlet Temperature (DMCW Side) = 47.1 Deg C
3.3	Outlet Temperature (ACW Side) = 50.4 Deg C	Outlet Temperature (ACW Side) = 45.1 Deg C

All other specification requirements for Rate Contract of Plate Heat Exchangers (except for above), as specified in specification no. PE-TS-RC-179-N001 & Amendment No. 1, shall remain unchanged.