

Corrigendum - 1 dated 06/05/2024 to CPC Tender No. CPC TENDER NO.: BHEL / CPC / LRA / CHP-AHP / 25 / 006

Corrigendum - 1 to Tender for the work of "CIVIL STRUCTURAL AND ARCHITECTURAL WORKS OF CHP, AHP INCLUDING FOUNDATION OF CRUSHER HOUSE, TPS, TRESTLE, (OTHER THAN BTG ISLAND BUT INCLUDING STRUCTURE WORKS), STACKER & RECLAIMER, BIOMASS SYSTEM AND MISCELLANEOUS BALANCE CIVIL WORKS AT 2X800 MW NTPC LARA STPP STAGE II, RAIGARH, CHHATTISGARH STATE, INDIA

A) Time Extension: Clause No. 1.0 Salient Features of NIT in NOTICE INVITING TENDER is revised as below:

Sl. No.	Clause No.	Existing in Tender	Revised As
1	Sl. No. v) DUE DATE & TIME OF OFFER SUBMISSION.	Date: 06/05/2024, Time: 10:00 Hrs	Date: 14/05/2024, Time: 10:00 Hrs
2	Sl. No. vi) OPENING OF TENDER	Date: 06/05/2024, Time: 16:30 Hrs	Date: 14/05/2024, Time: 16:30 Hrs

B) Some of the Bidders had asked queries in the published tender specification. The clarifications issued by BHEL are furnished below:

Sl. No.	Reference clause of Tender Document	Existing Clause	Bidder's Query	BHEL's Response
1	BOQ CUM RATE SCHEDULE Item no. B201,A202	Design Mix Concrete of grade M7.5 & M10 (with partial replacement of river sand by mass with coarse bottom ash).	Kindly provide the rate of Coarse bottom ash. You are also requested to provide design mix with Coarse bottom ash for M7.5 grade & M10 grade of concrete.	Bidders are requested to collect the information regarding applicable rate of coarse bottom ash during site visit in line with clause no. 1.0 of TCC. Design Mix for all concreting is in the scope of bidder; please refer clause no. 2.8.4 of TCC.
2	BOQ CUM RATE SCHEDULE Item no.308.	Inner and outer faces of wind shield with slip form shuttering:	Kindly provide the drawing of Silos with dimensions.	Drawings will be provided to successful contractor in phased manner after award of work. Please refer TCC Clause No. 2.5.8

Corrigendum - 1 dated 06/05/2024 to CPC Tender No. CPC TENDER NO.: BHEL / CPC / LRA / CHP-AHP / 25 / 006

Sl. No.	Reference clause of Tender Document	Existing Clause	Bidder's Query	BHEL's Response
3	BOQ CUM RATE SCHEDULE Item no.1808,	Laying of earthing mats/rods including risers, transportation from yard stores, loading, unloading, cutting to length, welding, protective painting of joints etc. all complete. (Excavation & Back filling shall be paid separately under respective item of earth work. Earthing mats/rods shall be supplied by BHEL free of cost)	Kindly provide the detailed drawing of earthing mats and pits.	Detailed Drawings will be provided to successful contractor in phased manner after award of work. Please refer TCC Clause No. 2.5.8
4	BOQ CUM RATE SCHEDULE Item No. 1809	Construction of below ground earthing system test pits as per drawing / sketches including concreting, reinforcement, formwork, providing & fixing GI strip etc as per drawing and specification (excavation & backfilling only will be paid under applicable BOQ items & cement/steel to be supplied by BHEL free of cost)		
5	BOQ CUM RATE SCHEDULE Item No.1810	Construction of below ground earthing system test links as per drawing/ sketches including concreting, reinforcement, formwork, providing & fixing GI strip etc as per drawing & specification (excavation & backfilling only will be paid under applicable BOQ items & cement/steel to be supplied by BHEL free of cost)		
6	BOQ CUM RATE SCHEDULE Item No.1811	Construction of below ground earthing system earth electrodes as per drawing and specification. (Excavation and backfilling only will be paid under applicable BOQ items & steel shall be supplied by BHEL free of cost.)		

Corrigendum - 1 dated 06/05/2024 to CPC Tender No. CPC TENDER NO.: BHEL / CPC / LRA / CHP-AHP / 25 / 006

Sl. No.	Reference clause of Tender Document	Existing Clause	Bidder's Query	BHEL's Response
7	BOQ CUM RATE SCHEDULE Item No.1812	Construction of below ground earthing system - Earth connection and riser pig tails as per drawing and specification. (Excavation and backfilling only will be paid under applicable BOQ items& steel shall be supplied by BHEL free of cost.)		
8	TCC-BOQ CUM RATE SCHEDULE Item No.1813	Providing Earthing pit as per drawing with charcoal & salt, GI pipes, GI earth electrodes, GI wire, GI strips, brick chamber with covers including associated earthwork etc. all complete.		
9	BOQ CUM RATE SCHEDULE Item No.1814	Construction of below ground earthing system test pits as per drawing/ sketches including brickwork, plaster, providing & fixing GI strips/pipes, GI wires, covers etc as per drawing & specification including associated earthwork.		
10	BOQ CUM RATE SCHEDULE Item No. 1815	Providing and fixing GI rungs in concrete/brick walls having zinc coating of minimum 900 g/sqm etc. all complete.		
11	BOQ CUM RATE SCHEDULE Item No. A2301	Collection & Transportation of factory fabricated structure from BHEL Store, Erection and alignment of prefabricated structures.....	For the actual working of the Item no. A2301 we required the actual height of structure for erection work. Please Provide.	Maximum Height of Erection shall be approx. 80 metres. This is for bidders information only. However, actual height of structures shall be as per approved RFC drawings which shall be made available during execution of works.

Corrigendum - 1 dated 06/05/2024 to CPC Tender No. CPC TENDER NO.: BHEL / CPC / LRA / CHP-AHP / 25 / 006

Sl. No.	Reference clause of Tender Document	Existing Clause	Bidder's Query	BHEL's Response
12	TCC	Land for the labour Hutment	Land for the labour Hutment is provided by the BHEL or Not. Please clarify the availability of Land.	Please refer clause no. 3.9.2 of TCC: 'Land for labour colony shall be arranged by Contractor at their own cost as per availability outside project area within 5 Km'. Bidders are also requested to visit the site before bid submission in line with clause no. 1.0 of TCC.
13	TCC	Land for the Batching Plant	Please provide the Lead of Land where the Batching Plant is installed in the NTPC area	Land for Batching Plant will be provided within plant boundary. Bidders are requested to visit the site before bid submission in line with clause no. 1.0 of TCC.

Corrigendum - 1 dated 06/05/2024 to CPC Tender No. CPC TENDER NO.: BHEL / CPC / LRA / CHP-AHP / 25 / 006

Sl. No.	Reference clause of Tender Document	Existing Clause	Bidder's Query	BHEL's Response
14	PQR C-3	<p><u>PROFIT:</u> Bidder must have earned profit in any one of the Five financial years as applicable in the last Five financial years preceding the present (i.e. 2018-19, 2019-20, 2020-21, 2021-22, 2022-23 as on date). Bidders to submit audited Balance Sheet and Profit & Loss Statement for the year as supporting documents.</p> <p><u>Note:</u> 5. C-3: PROFIT: Shall be profit (PBT) earned during any one of the five financial years as in C-3 above.</p>	<p><u>Requested to change this clause as below:</u></p> <p><u>PROFIT:</u> Bidder must have earned profit in any one of the Five financial years as applicable in the last Five financial years preceding the present (i.e. 2018-19, 2019-20, 2020-21, 2021-22, 2022-23 as on date). Bidders to submit audited Balance Sheet and Profit & Loss Statement for the year as supporting documents.</p> <p><u>Note:</u> 5. C-3: PROFIT: Shall be profit (Profit Before Tax-PBT or Profit after Tax-PAT whichever is higher) earned during any one of the five financial years as in C-3 above. (OR) Alternatively, you may please consider to delete this clause since Networth clause is more appropriate to assess the financial strength of a company.</p>	Tender Conditions Prevail.

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

for BHARAT HEAVY ELECTRICALS LTD
AGM / SCT- CPC