

Corrigendum – V dated 27/04/2026 to CPC Tender No. BHEL/CPC/YNR/M_BLR_ESP_PCP/27/007

Work Description - Erection, Testing, Commissioning, Trial Operation & Handing Over of Power Cycle Piping, Boiler and its auxiliaries including ESP, Pressure Part, Non-Pressure Parts, Duct dampers and its support structure, Rotating Equipment's, Air Pre-Heaters, ID/FD/PA fans, Mills, Refractory , including Handling of materials at BHEL / Client's Stores / Storage Yard and transportation to site, preparation of foundation, fixing of hangers & supports, application of lining, Insulation, supply & painting, Stenciling & Labelling of 1X800 MW DCRTPP, HPGCL, YAMUNA NAGAR, HARYANA, INDIA.

Some of the Bidders had asked queries in the published tender specification. The clarifications issued by BHEL are furnished below:

SL. No.	Reference Clause of Tender	Existing Provision	Bidder's Query	BHEL's Reply
1	TCC – Volume-IA, Chapter-XIV: ERECTION, Clause no.-14.22.16 and 14.34.35 AND sl. No.-20 of Section-C of Corrigendum-IV	In case of any class of work for which there is no such specifications as laid down in the contract such as blue matching, welding of stainless-steel parts etc., the work shall be carried out in accordance with instructions and requirements of the BHEL engineer at the quoted rates only.	Kindly specify the Qty. of SS Material for the estimation of cost.	Tender condition prevails.
2	TCC – Volume-IA, Chapter-XIV: ERECTION, Clause no.-14.22.30	The bidder may require to cut fins further to a maximum length of 1000 mm for alignment and welding of tube to tube in water wall/spiral wall panels and welding of fins on both sides after completion of panel to panel welding within the quoted rate. No extra payment will be made for the above works. Additional fins cutting as required for proper fit up of the joints shall be preferably to be done at ground during pre-assembly. NO FINS CUTTING IS PERMITTED BY GAS CUTTING; ONLY GRINDING/ CUTTING WHEEL SHALL BE PERMITTED TO CUT THE FINS.	Please specify the Qty. of Tubes to be aligned and welded for the estimation of cost	Tender condition prevails.

Note:

- 1) All other terms and conditions against this NIT shall remain unchanged.
- 2) This corrigendum is to be submitted duly signed and stamped along with the Techno-commercial bid (Part- I).

for BHARAT HEAVY ELECTRICALS LTD
SDGM/ Purchase- CPC