

Corrigendum-VI to RFQ No. RAJBOS0083 dtd 18-12-2021

S.No	Reference Document	Page No.	Clause No.	Description in the Clause/document	To be Read as / Change / Revision
1	Corrigendum-IV Sl.No.1	1/53	1	This project being funded by EXIM bank of India; vendor supply items can have a maximum of 10 Crores of foreign content (Non-Indian)	This project being funded by EXIM bank of India; vendor supply and service items can have a maximum of 10 Crores of foreign content (Non-Indian) The vendor list for all items to be submitted along with the offer for BHEL's approval. The list approved by BHEL shall be final.
2	Corrigendum-IV Sl.No.27 PS-439-1380 Technical Specifications	25/53	5.01-2	PV Module Wattage: 425 Wp to 545 Wp	PV Module Wattage: 525 Wp to 540 Wp. PV module Junction box cable length shall be minimum 300 mm for the negative terminal and 160 mm for the positive terminal
3	Corrigendum-I CEB Appendix A EMPLOYER'S REQUIREMENTS (02_Encl1_CEB_Tender _Document_Part1-9- 2021-12-23-09_00_09)	34/558	2.1	The Contractor shall also provide costing for a support and maintenance contract for a period for 3 years (renewable on a yearly basis, subject to satisfactory performance). Support and maintenance contract shall abide to the Service Level Agreement provided in the Technical Schedules.	Stands deleted.
4	Corrigendum-IV Price Bid and Unpriced Bid	04 to 09 /53	NA	Bidders to quote the Total FOR value at Sl.No.F and G. Break up of prices shall be calculated based on the % allocation as per BBU Sheet	Bidders to quote the Total FOR value at Sl.No.F and G. Vendor shall quote the prices so that percentage allocation of part A shall be in between 35% to 65%, part B shall be in between 9% to 19%, part C shall be in between 22% to 42% and part D shall be in between 2% to 4% of the total cost 'F' Given list of items are indicative billing break-up. Vendor shall propose the percentage allocation for the respective line items during detailed engineering which is subjected to BHEL's approval

5	Corrigendum-I CEB Appendix A EMPLOYER'S REQUIREMENTS (02_Encl1_CEB_Tender _Document_Part1-9- 2021-12-23-09_00_09)	27/558	2.35	The training shall be for at least two weeks. This shall include classroom lectures and hands-on training. The Contractor shall bear the costs associated with the travel from Mauritius and for accommodation and subsistence costs.	Training, travel, accomodation and subsistance shall be in BHEL scope. Necessary training from respective OEMs as per the specification shall be arranged by vendor.
6	Corrigendum-I CEB Appendix A EMPLOYER'S REQUIREMENTS (02_Encl1_CEB_Tender _Document_Part1-9- 2021-12-23-09_00_09)	52/558	4.2.1.	Price for Additional Capacity The Contractor is required to submit, along with his base bid, the cost for the installation of additional capacity in the range of 0.2MWac up to 1.8 MW ac. The price shall be in step of 0.2MWac of additional installed capacity and shall not be included in the Contract Price. This pricing is Mandatory and shall be quoted separately but will not be considered for evaluation purposes.	Stands deleted.
7	Corrigendum-I CEB Appendix A EMPLOYER'S REQUIREMENTS (02_Encl1_CEB_Tender _Document_Part1-9- 2021-12-23-09_00_09)	278/558	14.8	The tests for which a reduction in the Contract Price is defined are those necessary to prove the Guaranteed PV Farm Net Electrical Output (MWac)G If the Contractor fails to meet any of these guaranteed performances, the compensation detailed below shall be cumulative and shall be in addition to all other damages specified in the Conditions of Contract. If the Measured PV Farm Net Electrical Output (MWac)M is within 5-percent compared to the Guaranteed PV farm Electrical Output (MWac)G from the Contractor, then the Project is considered to have met the Guaranteed Project capacity rating. No additional payment will be made to the Contractor in the event that PV farm actual performances exceed the guaranteed performance values to the Employer's benefit.	Performance Guarantee & LD Clause is not applicable to the vendor. Designing of the equipment with in the limits of tender specifications shall be in vendor's scope.