

To
ALL BIDDERS,

Sub: Corrigendum-01: Changes in Technical Conditions of Contract

JOB: Electrical Package of Unit#1 and BOP of 3x800MW PVUNL Patratu Project

Reference:

1) E-Tender Specification Number: E-Tender Specification Nos: BHE/PW/PUR/NTPRT-ELE/2474

Bidders to kindly take note of the following:

AA) The following clauses shall be added to Chapter-II Scope Of Work of Vol IA TCC:

Clause No.	Clause description
2.28.1	Any additional wiring, cutting and fabrication on customer 3.3/ 6.6kV panel, need to be done by the subcontractor
2.28.2	Each oil drum must be tested for BDV (average of 5 reading)
2.28.3	Contractor should bring 10kl-2 Tanks for oil filtration
2.28.4	Impact recorder transportation to supplier for analysis
2.28.5	Drying out of electrical equipment like HT/ LT motor is in scope of sub-contractor
2.28.6	Temporary Area lighting for electrical commissioning need to be arranged by bidder
2.28.7	The vendor has to take care of TAG-IN /TAG-OUT permit system for working and operation of Electrical equipment
2.28.8	DG Commissioning: Diesel required for commissioning of DG set shall be in the scope of the vendor

BB) The following clause stands deleted from Chapter-VII Terms of Payment of Vol IA TCC

The unit rates quoted by the bidder shall be firm for a variation of quantities limited to $\pm 30\%$ of total order value corresponding to BOQ of Main equipment supply as above till finalization of engineering details & BOQ

CC) Due date of offer submission has been extended upto 30/09/2021 13:00. Technical bids shall be opened on 30/09/2021 17:00 Hrs

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL <https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

GM (Purchase)