



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-23-May-22

CORRIGENDUM- 01

<b>PROJECT</b>	:	4x210 MW & 3X500 MW NTPC KAHALGAON FGD
<b>PACKAGE</b>	:	<b>Gypsum Dewatering Equipment (Vacuum Belt Filter Type)</b>
<b>ENQUIRY NO</b>	:	PE/PG/KAG/E-6958/2022 dtd 25.04.2022
<b>SUBJECT</b>	:	<b>Technical amendment + DUE DATE EXTENSION</b>

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

In reference to the above mentioned tender enquiry for **Gypsum Dewatering Equipment (Vacuum Belt Filter Type)** package.

Please note the following:

1. Amendment-01 to the technical specification is attached along with this corrigendum, bidders who have already submitted their offer may revise their offer accordingly and bidders who have not submitted their offer requested to go through the same and quote accordingly.
2. Due date for offer submission has been extended till 30/05/2022 (till 11:0AM) and P1 to be opened on 04:00 PM on 30/05/2022.

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Guru Das  
Manager



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Ammendment-01 to technical specification

AMENDMENT DESCRIPTION:

S. No.	Section/Clause/Page No.	Existing	To be read as
1	Section-I/ sub section-IC/ clause 2.1.1.4/ pg 21 of 575	Filtrate extraction pumps 4 nos., (2 nos. /receiver tank: 1 working + 1 stand by) shall be provided.	Filtrate extraction pumps 2 nos., (1 no. /receiver tank) shall be provided.

Corrigendum