

Ref: BHE/PW/PUR/NTPRT-LP-PIPING/2974/Corg 01

Dt: 18/06/2024

Page 1 of 1-----

ALL BIDDERS

Sub: Corrigendum-01: Clarification

Job: Handling at site stores / storage yard, transporting to site, inspection, preassembly, erection, alignment, welding, NDT, fixing of hangers & supports, chemical cleaning / pickling, oil flushing, water flushing, hydro testing & steam blowing, surface finish, supply & application of primer & finish paints/ Anti corrosive / Wrapping and coating as applicable including labelling & flow direction on the piping / over insulation & hangers and supports, pre-commissioning, commissioning, trial operation & handing over to customer for, ACW,ECW ,ECW station piping, Rack Piping and misc. LP piping, ACW piping and its associated items /systems, hangers and supports, valves of Unit#1,Unit#2 & Unit#3 at PVUNL PROJECT PATRATU

Tender Specification Number: BHE/PW/PUR/NTPRT-LP-PIPING/2974

NIC Tender ID: 2024_BHEL_37047_1

Bidders to kindly take note of the following:

AA) Bidders to take note of the following clarification:

One of the prospective bidder has asked total scope joint details (per size and thickness) and details are as follows:

Please refer below table for approx. joints

Area	Pipe size	Details	Approx Joints (Joints may increase or decrease due to site routing)
ACW Piping (Underground)	900 NB	U#1 Supply	12
	900 NB	U#2 Supply	20
	900 NB	U#3 Supply	15
	1800 NB	Return	20
	1400 NB	Return	10
ECW Piping (Underground)	700 NB	ECW Supply	18
		ECW Return	18
	450 NB	ECW Supply	10
		ECW Return	10
	150 NB	ECW Supply	24
	150 NB	ECW Return	24
Misc Piping in Pump House (ACW & clarified water)	150 NB & Above	Including pipes/Fitting/valves/etc	1600 (from 25 NB to 450 NB)

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum/ digitally signed.

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
 Yours Sincerely,

(Purchase)