

Ref: BHE/PW/PUR/RGMT-STRUCTURE-PKG-A-2622/PKG-B-2623/Corg-02

Date: 06/09/2022

To,  
ALL BIDDERS,

**Sub: Corrigendum-02: Issuance of Clarifications.**

**Scope of Work: PACKAGE-A:** Handling of materials at BHEL / Client's Stores / Storage Yard and transportation to site Erection, Testing, Assistance for commissioning & Trial Operation including supply & application of final painting and Handing Over of Flue Gas Desulphurization System (FGD) of Stage -I (Unit # 1, 2 & 3) Including Storage Silo Fabrication & erection, Silo SS liner Fabrication & Erection, Erection of Common Structures for the FGD Project and fabrication including painting of one number Dry Ash Silo of ESP R & M stage-II (unit # 4, 5 & 6) project.

and

**PACKAGE-B:** Handling of materials at BHEL / Client's Stores / Storage Yard and transportation to site Erection, Testing, Assistance for commissioning & Trial Operation including supply & application of final painting and Handing Over of Flue Gas Desulphurization System (FGD) of Stage-II (Unit #4, 5 & 6) including E&C of common system for the Project (excluding Structure).

at 3x200MW + 3X500 MW NTPC Ramagundam, Stage- I & II, Telangana

References:

1. E-Tender Spec No: BHE/PW/PUR/RGMT-STRUCTURE-PKG-A-2622/PKG-B-2623 dt-17/08/2022  
NIC Tender ID: 2022\_BHEL\_16638\_1

Bidders to kindly take note of the following:

**AA) ISSUANCE OF CLARIFICATIONS:**

Sl. No	Reference Document	Reference Chapter/Annexure	Reference Clause	Tender	Query/Clarification Required	BHEL Reply
1	TECHNICAL CONDITIONS OF CONTRACT (TCC)- VOLUME-IA	Chapter-II: Scope of work	Page 70 of 169 Vol-IA TCC under chapter scope of work: Important information for the fabrication & erection work of		<b>a. Limestone Day Silo:</b> 2 nos Day Silo <input type="checkbox"/> <input type="checkbox"/> Fabricated segment of limestone day Silo shall be dispatched to site. All segments shall be welded as per Limestone day Silo site fabrication drawings.	<ul style="list-style-type: none"><li>Yes, vendor means contractor.</li><li>For thickness etc. refer drawing (attached).</li></ul>

Ref: BHE/PW/PUR/RGMT-STRUCTURE-PKG-A-2622/PKG-B-2623/Corg-02

Date: 06/09/2022

Sl. No	Reference Document	Reference Chapter/Annexure	Reference Clause	Tender	Query/Clarification Required	BHEL Reply
			structure under this tender specification		<p>Query- Vendor means Contractor ?</p> <p><input type="checkbox"/><input type="checkbox"/>Pre- Assembly, Erection, Alignment, Welding and NDT shall be in the scope of contractor.</p> <p>Query-Kindly Provide the thickness of plate .</p>	
2	TECHNICAL CONDITIONS OF CONTRACT (TCC)- VOLUME-IA	Chapter-II: Scope of work	-do-		<p><b>b. Limestone Storage Silo (4 nos)</b></p> <p><input type="checkbox"/><input type="checkbox"/>BHEL will provide the structural steel/ plates (MS &amp; SS) to the vendor free of cost for fabrication of Limestone storage silo</p> <p>Query-We understand Raw rolled steel shall be provided by BHEL . Kindly Provide the thick ness of plate.</p>	<ul style="list-style-type: none"> <li>Raw structural steel/plate material will be provided by BHEL free of cost. Further cutting, bending etc as per TCC in contractor scope</li> <li>For thickness etc. refer GA drawing (attached). Further, detailing from GA drawing is in the scope of vendor.</li> </ul>
3	TECHNICAL CONDITIONS OF CONTRACT (TCC)- VOLUME-IA	Chapter-II: Scope of work	-do-		<p><b>c. Dry Ash Silo (01 no pertaining to ESP R &amp; M stage-II)</b></p> <p>Query-We understand Raw rolled steel shall be provided by BHEL . Kindly provide the thick ness of plate.</p>	<ul style="list-style-type: none"> <li>Raw structural steel/plate material will be provided by BHEL free of cost. Further cutting, bending etc as per TCC in contractor scope</li> <li>For thickness etc. refer GA drawing (attached). Further, detailing from GA drawing is in the scope of vendor.</li> </ul>

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.



**Ref: BHE/PW/PUR/RGMT-STRUCTURE-PKG-A-2622/PKG-B-2623/Corg-02**

**Date: 06/09/2022**

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → <https://eprocarebhel.co.in>  
BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,  
Yours faithfully,

GM (Purchase)