



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-8-Aug-23

CORRIGENDUM- 02

PROJECTs	:	5X800 MW YADADRI TPS (Stage-2)
PACKAGE	:	VENTILATION SYSTEM (PART-III)
GeM Bid NO	:	E-7312/2023 Dated 31.07.2023
SUBJECT	:	Technical Amendment

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

Bidders are requested to go through the following -

1. Refer attached technical amendment#1

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sumeet
t Sahay

Digitally signed by
Sumeet Sahay
DN: cn=Sumeet Sahay,
o=BHEL, ou=PEM,
email=sumeetsahay@bhel
l.in, c=IN
Date: 2023.08.08 16:23:15
+05'30'

Sumeet Sahay
Manager/BOP

Technical Amendment#1



5x800MW YADADRI STPP(STAGE 2)
VENTILATION SYSTEM-Axial Fans(PART 3)

SPECIFICATION NO. PE-TS-417-554-
A003

Annexure A

DATE: 07/08/2023

SHEET 2 OF 3

AMENDMENT TO EXISTING CLAUSES OF TECHNICAL SPECIFICATION

Sl. No.	Clause	Existing description	To be read as (Amendment)				
1	Section-I, Sub- section-(Civil Requirements) Page no 13 of 337 of Technical specifications	Roof extractor units with 15 mmwc static pressure.	Roof extractor units with 15 mmwc static pressure.				
		Capacity	Motor rating	Roof /Slab opening	Capacity	Motor rating	Roof /Slab opening
		50,000cmh	5.5KW	1320 Ø mm	50,000cmh	5.5KW	1256 Ø mm
2	Section-II, Sub- section-8 (Input Drawing section), Page no 334-335 of 337 of Technical specifications	Battery room with ducting is shown	Supply and E&C of Ducting required from Exhaust of Fan to atmosphere shall be in BHEL scope.				
3	Section-II, Sub- section-6, (make declaration by bidder), Page no 147 of 337 of Technical specifications	Make declaration by bidder	Revised Make declaration by bidder attached				

Make Declaration by Bidder

(To be furnished by the bidder along with the bid)

Rev 01

Sheet 3 of 3

Project:5x800MW Yadadri TPS Stage II

Package: Ventilation System - Axial Fans

Tender Enquiry Number:

Bidder:

Bidder to provide following details that will be part of the contract:

SI No	Name of Item	Approved Makes	Any other preferred make bidder wishes to offer (for which negative price impact is furnished by the bidder in their bid)
1	Axial Fans (Roof extractor, Supply and Exhaust fans)	<ol style="list-style-type: none">1. FLAKT, GREATER NOIDA2. KHAITAN, KOLKATA3. PATEL AIR, AHMEDABAD4. KRUGER, SINGAPORE5. MARATHON, KOLKATA6. CB DOCTOR,7. ALMONRAD CHENNAI8. TCF NADI, CHENNAI9. AVPL, DELHI10. SK SYSTEMS, DELHI	_____ (Specify name of the make) *

* - Bidder shall provide its bid compliant to above approved makes. However, BHEL shall seek approval of bidder's preferred make of Axial fans (as per above table) from customer. In case, preferred make indicated by the bidder is approved, negative price impact given by bidder in Annexure III of price format shall be exercised.

* - Bidder to submit relevant credentials such as Purchase order/inspection report / dispatch details/ performance certificate/ any such document required by end customer etc. of proposed make, along with their offer for taking up with customer for approval.

Date:

(Bidder's Representative)

Sign & Stamp