

Ref: BHE/PW/PUR/BCKSR BLR CAP ADDN U1 U2/2431/Corg-02

Date: 08/07/2021

Page 1 of 2

To,

ALL BIDDERS,

**Sub: Corrigendum-02: Clarifications**

**Job:** WORK FOR CAPACITY ENHANCEMENT OF 100TPH AFBC BOILER UNIT # 1 & 2 AT BIRLA CELLULOSIC PLANT KHARACH, KOSAMBA GUJARAT.

**E-TENDER SPECIFICATION NUMBER:** BHE/PW/PUR/BCKSR BLR CAP ADDN U1 U2/2431

**Bidders to kindly take note of the following:**

**AA) Clarifications:**

S N	Reference clause of TCC of Tender Document- VOLITechBid2431	Existing provision	Bidder's Query	BHEL Clarifications
1	Chapter II - Scope of work/Erection/ clause: 21 /page No. 54 of 89	Chemicals (Tri-sodium phosphate & di-sodium phosphate) for alkali boil out to be arranged by agency. (Quantity- 200 kg each (approx.) per unit) Agency for procurement of chemical to be confirmed by BHEL engineer & test certificate to be submitted.	Kindly provide the agency details for supply of chemicals for the work	Agency for procurement to be arranged by bidder. Chemicals to be arranged by bidder. Quantity mentioned is in the clause 21 on page 54. BHEL engineer will provide concurrence for the same. Test certificate of the chemicals procured to be submitted. These are general chemicals being used in power plants and are easily available. It can be procured from any reputed supplier.

Ref: BHE/PW/PUR/BCKSR BLR CAP ADDN U1 U2/2431/Corg-02

Date: 08/07/2021

Page 2 of 2-----

2	Chapter II - Scope of work/Erection/ clause: 24 /page No. 54 of 89	Manpower supports for Alkali boil out.	As per the scope Alkali Boil Out shall be arranged by Agency. But in some other area only manpower assistance. Kindly clarify Alkali BOil out scope	Bidder to arrange chemicals & provide manpower support for preparations & during the alkali boil process. Preparation of alkali boil-out includes laying of temporary line of 1" (around 10-15 mtr lenght) for sampling. The unit operation will be performed by Customer in BHEL supervision.
3	Chapter II - Scope of work/Erection /clause: 26/ page No. 54 of 89	Manpower support for Safety valve floating and manpower support for servicing of safety valve if required.	Manpower support for Safety valve floating and manpower support for servicing of safety valve if required.- For safety valve floating arrangement of agency in whose scope?	Bidder will provide manpower support during safety valve floating. Also, manpower support/necessary arrangement is to be provided by Bidder for safety valve servicing , if required. The safety valve setting will be done by BHEL Personnel.
4	Chapter II - Scope of work/Erection /clause: 20&25/ page No. 54 of 89	1. Erection of Temporary piping and valves for steam blowing & alkali Boil out. 2.Manpower support for Steam Blowing activity.	Manpower support for steam blowing- What will be the PMPL scope, only manpower support or pipes and plates installation work involved or not kindly clarify.	Temporary pipes, temporary structure for locking and valves will be provided by BHEL. Bidder to carry out erection of temporary circuit for steam blowing and restoration of the same after completion. Also, manpower support during steam blowing activity to be provided by the Bidder.

=====  
 All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → BHEL GeP NIC Portal i.e. <https://eprocurebhel.co.in>.

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,  
 Yours faithfully,

GM (Purchase)