

Ref: BHE/PW/PUR/BWT6-ELE/2427/Corg-02

Date: 15/06/2021

To,

ALL BIDDERS,

Sub: Corrigendum-02: Clarification

Scope of Work: HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, ASSISTANCE FOR COMMISSIONING AND HANDING OVER OF HT / LT POWER TRANSFORMERS, CABLING PACKAGE, ISOLATED PHASE BUS DUCT FOR GENERATOR TRANSFORMER, SEGREGATED PHASE BUS DUCT FOR STATION TRANSFORMER / UNIT AUXILIARY TRANSFORMER, ELECTROSTATIC PRECIPITATOR, FLUE GAS DESULPHARIZATION SYSTEM, CHP/AHP HT SWGR, STATIC EXCITATION SYSTEM, GENERATOR CONTROL & PROTECTION PANELS, ABOVE/BELOW GROUND EARTHING AND LIGHTNING PROTECTION SYSTEM ,11kV/6.6kV/3.3kV/0.415kV SWITCHGEAR BOARDS / MCC, SOOT BLOWER SYSTEM, EXCITATION SYSTEM, 220 VOLT BATTERY SYSTEM, TESTING & COMMISSIONING OF DG SETS, ITS ASSOCIATED EQUIPMENTS INCLUDING BOP PACKAGE ALONG WITH ILLUMINATION PACKAGE FOR **BHUSAVAL TPS, UNIT-6, 1x660 MW, MAHAGENCO PROJECT.**

References: -

1. E-Tender Specification Nos: BHE/PW/PUR/BWT6-ELE/2427

Bidders kindly to take note of the following:

AA) ISSUANCE OF AMENDMENT:

SI No	Item No	Existing Clause	Amended as
1	Clause no 2.8.A.9 of Volume IA	Contractor shall arrange storage tank of approx. 10 kilo litre capacity, internally sand blasted and with one coat of oil resistance paint. Oil from drums to be transferred in storage tank and filtration to be carried out to achieve the required BDV/ withstand value. This treated oil to be filled in the transformers and auxiliaries. However, for low capacity transformer, a separate storage tank for mass filtration may not be required	Contractor shall arrange 2 number storage tank of approx. 10 kilo litre capacity each, internally sand blasted and with one coat of oil resistance paint. Oil from drums to be transferred in storage tank and filtration to be carried out to achieve the required BDV/ withstand value. This treated oil to be filled in the transformers and auxiliaries. However, for low capacity transformer, a separate storage tank for mass filtration may not be required.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

पावर सेक्टर- पश्चिमी क्षेत्र Power Sector-Western Region
श्रीमोहनी काम्पलेक्स, 345 किंग्सवे, नागपूर Shreemohini complex, 345 Kingsway Nagpur - 440 001
फोन / Phone 0712- 2858600, फैक्स FAX: 0712-2858699 www.bhelpswr.co.in

Ref: BHE/PW/PUR/BWT6-ELE/2427/Corg-02

Date: 15/06/2021

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL→ www.eprocurebhel.co.in

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

GM (Purchase)