

Ref: PW/NGP/PUR/2006129/Corg-02

Date: 23/12/2020

To

ALL BIDDERS,

Sub: Corrigendum-02: Issue of Clarifications

S. No.	PW/NGP/PUR/2006129
--------	--------------------

FOR

Scope of Work: HIRING RMX AGENCY FOR INSTALLATION OF BATCHING PLANT, PRODUCTION OF REQUIRED GRADE OF CONCRETE, CONVEYING AND PLACEMENT/POURING OF CONCRETE IN FOUNDATION INCLUDING CEMENT, AGGREGATE, SAND MIXTURE, ETC. AS PER SCOPE OF WORK AT **2X250 MW NSPCL BHILAI FGD PROJECT.**

Reference:

- 1) E-Tender Specification Number: PW/NGP/PUR/2006129
- 2) Corrigendum-01 Dated 22/12/2020 for Clarifications and Due date extension from 22/12/2020 to 28/12/2020

Bidders to kindly take note of the following:

AA) Issue of Clarifications:

Sr. No.	Documents Reference	Tender Terms & Condition	Bidders' Query	BHEL Clarification
1	-----	General	For design mixing purposes, a chemical test of the aggregate is required or not.	Please refer Tender Condition, it is self-explanatory
2	-----	General	If the chemical test is required and the test will be failed, in this condition we have to manage material from other sources for again testing. This process takes extra time and money also if the distance between the source and site will	Tender Condition Shall prevail, all this is part of bidder's responsibilities and scope. No compensation in term of time and amount shall be provided on account of this reason

Ref: PW/NGP/PUR/2006129/Corg-02

Date: 23/12/2020

Sr. No.	Documents Reference	Tender Terms & Condition	Bidders' Query	BHEL Clarification
			be increased then transportation charges will be increases also. For this purpose will we get an extra amount and time?	
3	-----	General	Has BHEL already approved any source of construction material for this purpose, if yes please share us the details.	Bidders has to identify approved source/quarry of Govt. and propose it for approval from NSPCL Bhilai. Sample testing and its approval as per customer specification, responsibilities lies with agency.
4	-----	General	You have already mentioned the approved laboratory National Council for Cement and Building Materials (NCB), Ballabgarh and also mentioned about other laboratories, please share us the list of other laboratory too	Approved list of Laboratory of NSPCL Bhilai shall be provided after award of contract. Tentative list is laboratory of repute such as CSMRS, NCBM, IITs, National Test House, Kolkata etc. as agreed by the Engineer. Customer decision shall be binding on agency.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL→
<https://eprocarebhel.co.in>.

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

AGM (Purchase)