

CORRIGENDUM-03

Ref: PE/PG/YAD/E-6606/2020/Corrigendum/03

Date: 26/02/2021

DUE DATE
08/03/2021
BY 02:00 PM (IST)

Project: 5X800MW YADADRI TPP

Package: SINGLE GIRDER EOT/HOT MISC. CRANES

References: Enquiry. No.: PE/PG/YAD/E-6606/2020 dated 16/02/2021

Subject: Corrigendum due to change in NIT & Technical Specification clauses:-

With reference to the above Tender Enquiry, Bidders to note the following:

1. The due date of bid submission for subject tender is extended from existing date 26/02/2021, 2:00 PM (IST) to 08/03/2021, 02:00 PM (IST). Part-I bids shall be opened on 08/03/2021, 04:30 PM.
2. Corrigendum to technical specification is enclosed herewith. Bidders are requested to submit the bid accordingly.
3. Bidders to note the following regarding BOQ/ Price Format Sheet: -

"Sum Formula appearing in uploaded BOQ in cell no BA401 is – SUM(BA18:BA400). However, it should be SUM(BA15:BA400) i.e. Sum of BOQ starting from 15th row to 400th row. Accordingly, bidders to note that Sum of all cranes (from 15th row to 400th row) will be recalculated by BHEL after the price bid opening. This revised sum shall be considered further ordering process."

There is no other change in subject tender terms & conditions.

Thanking You

With regards
For & on behalf of BHEL
Rohit Juneja
Dy Manager | PG II, BHEL PEM | Noida

कृपया प्रेषित करें :
बीएचईएल, पीएस-पीईएम
पीपीआई भवन
प्लॉट नं २५, सेक्टर १६ ए
नोएडा - २०१ ३०१ उ प्र
भारत

Please reply to :
BHEL, PS-PEM,
PPEI Building,
Plot No.25, Sector 16A,
Noida-201301 (U.P.)
INDIA

फ़ोन Phone No:
91-120 – 436 8848

पंजीकृत कार्यालय
बीएचईएल हाउस
सीरी फोर्ट
नयी दिल्ली – ११० ०४९
भारत

Registered Office :
BHEL House,
Siri Fort,
New Delhi-110049
INDIA



**5 X 800 MW YADADRI TPP
PACKAGE: SINGLE GIRDER CRANES**

TECHNICAL CORRIGENDUM – 1 TO SPECIFICATION NO. PE-TS-417-524-A001 DATED 22.02.2021

S N	Clause	Page No.	Statement of the referred clause	Statement should be read as
1	2.9.2	194 of 225	Rating (KW) - * (*) indicates that the bidder shall fill Technical details during detailed engineering only.	Rating (KW) [Minimum rating shall be as indicated For 5T Cranes: MH – 5.5 KW, CT – 1.1 KW, LT – 1.1 KW For 8T Cranes: MH – 7.5 KW, CT – 1.1 KW, LT – 1.1 KW For 10T Cranes: MH – 9.3 KW, CT – 1.1 KW, LT – 1.1 KW