



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date: 26 Aug 2021

CORRIGENDUM- 03

PROJECT	:	2 X 660 MW THDC KHURJA-TG
PACKAGE	:	D/G EOT CRANES UP TO 100T
ENQUIRY NO	:	PE/PG/THD/E-6723/2021 Dated 07.08.2021
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☐

Please note the following:

Reply to Pre-Bid Clarification attached with this corrigendum shall be treated as part of NIT.

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP



2X660 MW THDC Khurja STPP
PACKAGE: DOUBLE GIRDER EOT CRANES BELOW 100T

SPECIFICATION No: PE-TS-475-501-A502

VOLUME: III

SECTION-III

SUB-SECTION-IIIC

REV 00

DATE 26.08.2021

SUB SECTION-IIIC
PRE BID CLARIFICATION



2X660 MW THDC Khurja STPP
PACKAGE: DOUBLE GIRDER EOT CRANES BELOW 100T

SPECIFICATION No: PE-TS-475-501-A502

VOLUME: III

SECTION-III

SUB-SECTION-IIIC

REV 00

DATE 26.08.2021

PRE-BID CLARIFICATION

S. No.	Section/Clause/Page No.	Statement of the referred clause	Clarification Required	BHEL's clarification
1	-	In Specification mentioned only requirement is for "Boiler Feed Pump" but not mentioned whether it's under Safe Area OR Hazardous Area ?	Kindly confirm area where crane to be installed Safe Area OR Hazardous Area?	Specification requirement is clear. In tender technical specification, there is no requirement of hazardous area crane. Hence cranes under the scope of tender should be considered to be installed in non-hazardous area.